

POLE MOVING FRAME

GENERAL

NOTES CONCERNING THIS ADDENDUM

This addendum supplements Section G21.416.1, Issue 1 with new instructions covering the required clearances between power wires and telephone plant at points of crossing or between any part of a telephone pole and power wires. The cross-reference, "See Addendum" should be written at Paragraph 2.03 in Section G21.416.1 which is replaced herein.

2. PRECAUTIONS

2.03 If this preliminary check indicates that the separation between power wires and telephone plant at points of crossing, or between any part of the telephone pole and power wires would at any time be less than the minimum clearance values shown in Section G10.301-S for the State of California or Section G10.301 for Nevada, either have the electric wires deenergized during the period the move is being made, or lower the telephone attachments sufficiently to insure adequate clearance throughout the move. If unable to do either of the above, the pole should not be moved by the PM Frame method.