

POLE REPLACING  
ORIGINAL LOCATION

NOTES CONCERNING THIS ADDENDUM

This addendum is being issued to specify the 7 ft. 6 in. measurement from ground line to first pole step which applies in this area. It also provides an alternate method for snubbing of the lower portion of poles to be cut off near the ground line and the pole jack method is used.

"See Addendum" should be marked in G21. 435. 1 to indicate the following:

- Paragraph 2. 02 - Replaced
- Paragraph 4. 02 (2) - Supplemented

2. SAFETY PRECAUTIONS

2. 02 Stepped poles which have been cut off at the ground line and not immediately taken down shall have all steps removed up to a distance of at least 7 ft. 6 in. above the ground.

4. POLE JACK METHOD

4. 02 (2) Where it is impractical to snub the lower portion of the pole with rope slings to digging bars due to fences, buildings, etc., set the pole jack up as covered in paragraph 4. 02 (3) and proceed as follows:

- (a) Place one-inch rope sling around pole, passing ends through lower handle of jack, crossing as they pass through the handle.
- (b) Pull the rope sling snugly around pole and through jack handle.

- (c) Twist free ends of rope together to hold strain.
- (d) Hold rope in this twisted position until pole is cut off and raised a few inches to clear.
- (e) Untwist rope allowing pole to shift away from jack to side of butt.
- (f) Lower pole to ground, untwisting rope as required.