

## POLE REMOVAL

### GENERAL

#### NOTES CONCERNING THIS ADDENDUM

This addendum is being issued to provide for the 7 ft. 6 in. measurement, from ground line to first pole step, which applies in this area.

"See Addendum" should be marked in G21. 505. 1 to indicate the following:

Paragraph 2.06 - Replaced

#### 2. SAFETY PRECAUTIONS

2.06 Where stepped poles have been cut off and are not to be taken down immediately, all steps shall be removed within a distance of 7 ft. 6 in. above the ground line before leaving the job.