

STEPPING POLES

GENERAL

NOTES CONCERNING THIS ADDENDUM

This addendum has been issued to replace the information regarding stepping of Company owned poles when a complaint has been received to the effect that such poles have been climbed by unauthorized persons to gain access to roofs or for any other purpose.

The following should be marked "See Addendum" and treated as indicated.

Paragraph 1.03 Replaced

1. GENERAL

1.03 When a complaint is received from a customer, property owner, or occupant of premises adjacent to a Company owned pole to the effect that such pole has been climbed by unauthorized persons to gain access to roofs or for any other purpose, ALL of the steps below the work steps shall be removed from this pole. To prevent resteping, a metal tag bearing the words, "DO NOT STEP," shall be placed on the pole in accordance with the instructions for installing these tags, which will be found in the section covering, Marking Poles. Such action, however, shall not be taken in connection with any joint pole described in Paragraph 2.01 (d) of this section.