

STEPPING POLES
LOCATING LINE STEPS

NOTES CONCERNING THIS ADDENDUM

This addendum has been issued to include instructions to place three B Pole Step Mountings in all cases where these Mountings are required, also to omit the placing of spike-head pole steps 6 inches above the suspension strand where double guard arms or double crossarms are placed.

The following shall be marked "See Addendum" and treated as indicated.

- Paragraph 1.01 (c) - Replaced
- Paragraph 2.01 - Supplemented
- Paragraph 2.03 - Note added
- Paragraph 3.01 (a) - Replaced

1. GENERAL

1.01 (c) To clear the vertical plane in which drop wires may leave the pole as illustrated. The pole step at the level nearest the space reserved for drive hooks above the strand shall be moved in a horizontal plane toward the climbing space a distance of not more than $1/8$ the circumference of the pole. It may also be necessary to move the first step below the strand, if and when drive hooks and drop wires are placed that will interfere with the free use of this step.

2. LOCATING SPIKE-HEAD POLE STEPS

2.01 Three B Pole Step Mountings shall be placed in all cases where these Mountings are required. Pole A in the illustration on page 3 shall be changed to show three B Pole Step Mountings.

2.03 Note: Spike-head pole steps which are required 6 inches above the suspension strand may be omitted where double guard arms or double crossarms are placed.

3. LOCATING MOUNTINGS FOR DETACHABLE POLE STEPS

3.01 (a) If the lowest spike-head pole step has been placed 7 feet 6 inches from the ground line, place three B Pole Step Mountings with plates on alternate sides of the pole and equally spaced between the lowest spike-head pole step and the ground line.