

GUYING  
INSULATED WIRES

NOTES CONCERNING THIS ADDENDUM

This addendum has been issued to eliminate the use of Double The Recommended Sag when placing Rural or Urban Wire on Joint Use Lines.

The following should be marked "See Addendum" and treated as indicated.

Paragraph 2.01 - Note added

2. PLACED AT DOUBLE RECOMMENDED SAG

- 2.01 Note: When Urban or Rural Wire is placed on Joint Use Lines, Double The Recommended Sag shall NOT be used, place wire at recommended sag.