

GUYING
INSTALLING GUYS
WRAP METHOD

1. GENERAL

1.01 This appendix covers supplementary information concerning the installation of guy protectors on jointly used poles. This issue replaces Appendix G23. 145, Issue B.

2. GROUPING GUYS ON JOINTLY USED POLES

2.01 In some cases, guys will be found with sufficiently low tensions and separations such as will allow them to be drawn together and the group protected by a single shield. Guys belonging to the utilities listed below may be grouped with Telephone Company guys, if such grouping is practicable, without any special agreement being required. Where it is desired to group guys belonging to utilities other than those mentioned, the specific case shall be reported to the plant engineer who will make the necessary arrangements for obtaining approval. The following companies are agreeable to group guying when the circumstances warrant such guying:

Associated Telephone Company
California Electric Power Company
City of Anaheim
City of Burbank
City of Colton
City of Glendale
City of Los Angeles
City of Pasadena
City of Riverside
Los Angeles Transit Lines
Pacific Electric Railway
Southern California Edison Company
Western Union Telegraph Company