

GUYING  
INSTALLING GUYS  
EYE BOLT METHOD

1. GENERAL

- 1.01 This appendix covers supplementary information concerning the installation of guy protectors on jointly used poles.

2. GROUPING GUYS ON JOINTLY USED POLES

- 2.01 In some cases, guys will be found with sufficiently low tensions and separations such as will allow them to be drawn together and the group protected by a single shield. Guys belonging to the utilities listed below may be grouped with Telephone Company guys, if such grouping is practicable, without any special agreement being required. Where it is desired to group guys belonging to utilities other than those mentioned, the specific case shall be reported to the plant engineer who will make the necessary arrangements for obtaining approval. The following companies are agreeable to group guying when the circumstances warrant such guying:

Associated Telephone Company  
California Electric Power Company  
City of Anaheim  
City of Burbank  
City of Colton  
City of Glendale  
City of Los Angeles  
City of Pasadena  
City of Riverside  
Los Angeles Transit Lines  
Pacific Electric Railway  
Southern California Edison Company  
Western Union Telegraph Company