

OPEN WIRE JOINTLY USED POLES AND
POWER CROSSINGS - PREVENTION OF
FLIP - UPS AT LOW POLES

NOTES CONCERNING THIS ADDENDUM

This addendum supplements Section G31.109.1 and has been issued to specify the placing of an additional brace between the crossarm and guard arm at the pole.

"See Addendum" should be written at the drawing on Page 7 which is supplemented.

3. CROSSARM CONSTRUCTION

3.01 Page 7 where there is a clear space between the top of the pole and the guard arm, place an additional B or D Tandem Transposition Bracket or an S Reinforcing Strap attaching one end to the pole with a 1/2 X 4-1/2 inch drive screw and bolting the other end to the back of the guard arm.