

DROP AND BLOCK WIRE
SERVICE CONNECTIONS IN
AUTO-TRAILER CAMPS

NOTES CONCERNING THIS ADDENDUM

This addendum supplements Section G32. 157. 1 and has been issued to bring this section into conformity with the requirements of the California Department of Industrial Relations Division of Housing as set forth in the California Administrative Code Title 8, Chapter 9, Article 5.

The cross-reference, "See Addendum", should be marked at the illustration under paragraph 3. 02(b).

3. INSTALLING SERVICE DROPS

3. 02(b) Buried Service Connections

NOTE: Only B Underground wire will be used in this area for Buried Service Connections. Such installations will have a minimum cover of 24 inches and shall be located not less than one foot radial distance from water, sewer, gas, or buried power cables. Use 1" x 3" redwood or its equivalent for top protection on all installations.