

C RURAL WIRE
SPlicing AND TERMINATING

NOTES CONCERNING THIS ADDENDUM

This addendum has been issued to clarify instructions relative to attaching a protector ground wire to a power company multigrounded neutral.

The following should be marked "See Addendum" and treated as indicated:

Figure 6 associated with paragraph 3.02 - Supplemented

3. TERMINATION

3.02 The M. G. N. grounding conductor (multigrounded neutral) shown in figure 6 is used only by the Imperial Irrigation District. Where a protector is to be grounded to a multigrounded neutral the connection shall be made by power company workmen.