

© 1959

The Pacific Telephone and Telegraph Company

BELL SYSTEM PRACTICES  
Outside Plant Construction  
and Maintenance

ADDENDUM G34.801.8  
Issue A, August, 1959  
TPT&T Co.  
So. Co. Area

## C RURAL WIRE TERMINATING

### GENERAL

This addendum to Section G34.801.8, Issue 1, adds a restriction on the use of multi-grounded neutral conductors.

Paragraph 3.03 - Supplemented.

Write "See Addendum" at Paragraph 3.03.

### 3. TERMINATION AT DEAD-END POLES

3.03 Add note:

The M.G.N. Grounding Conductor (multi-grounded neutral) shown in the illustration will be used in the Imperial Irrigation District only. The Engineer will specify on the detailed plans when it is to be used, and only power company workmen shall make the connection.

ADDENDUM  
G34.801.8

Page 1  
1 Page

C RURAL WIRE  
TERMINATING