

PROTECTION

104A PROTECTOR MOUNTING

NOTES CONCERNING THIS ADDENDUM

This addendum supplements G38. 125. 1 and is issued to provide instructions for making attachment to power company vertical grounding conductors.

The cross-reference "see Addendum" should be marked in Paragraph 3.01 in G38. 125. 1, which is supplemented.

3. GROUNDING CONDUCTORS

- 3.01 Any connection made to a power company vertical ground conductor shall be made by the power company workman.