

PROTECTION

108A PROTECTOR

NOTES CONCERNING THIS ADDENDUM

This addendum supplements Section G38.130.1 and is issued to provide instructions for making attachments to power company vertical grounding conductors, and to delete reference to tool not adopted for use in this area.

The cross reference "See Addendum" should be marked in the main Section to indicate the following:

- Paragraph 3.01 - Supplemented
- Paragraph 4.04 - Supplemented

3. GROUNDING CONDUCTORS

- 3.01 Any connection made to a power company vertical ground conductor shall be made by the power company workman.

4. INSTALLATION

- 4.04 The B Voltage Tester referred to in this paragraph was not adopted for use in this Area and this portion of the paragraph should be marked accordingly.

Any connection made to a power company vertical ground conductor shall be made by the power company workman.