

CONDUIT AND MANHOLES

MATERIAL TABLES

NOTES CONCERNING THIS ADDENDUM

This addendum supplements Section G40.055.1 and covers certain legal requirements of the State of California.

The cross-reference "See Addendum" should be written in Section G40.055.1 at Paragraph 1.01 which is supplemented herein.

1. GENERAL

1.01 In California the minimum width of all manholes shall be 4 feet and the minimum headroom shall be 5 feet.