

MANHOLES
CONCRETE FORMS
ASSEMBLY DIAGRAMS

NOTES CONCERNING THIS ADDENDUM

This section supplements Section G43.120.3 and provides changes with respect to legal requirements in the State of California.

The cross reference "See Addendum" should be written at Paragraph 1.02, 3.02 and the drawings on pages 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, and 15.

1. GENERAL

1.02 In the table associated with this paragraph, the line of figures opposite and including 3 ft. 6 in., 4 ft. 0 in., and 4 ft. 6 in., shall be deleted. The minimum headroom for all manholes in California is 5 feet.

3. ASSEMBLY DIAGRAMS

3.02 In California, the inside dimensions of manholes shall be such that the width will not be less than 4 feet and the headroom not less than 5 feet.

Notes: The manhole form assembly and the list of parts for this assembly on Pages 4 and 5 of Section G43.120.3 shall not be used in the State of California.

The 3 ft. 6 in. ends in the manhole form assemblies and the list of parts for the assemblies on Pages 6, 7, 8, 9, 10, 11, 12, 13, 14, and 15 shall be disregarded and proper forms substituted to obtain the 4 ft. width required in the State of California.