

MANHOLES
CONCRETE FORMS
ERECTION OF FORMS

NOTES CONCERNING THIS ADDENDUM

This addendum supplements Section G43.120.5 covering erection details and the method of handling foreign structures.

The cross-reference, "See Addendum" should be written at Paragraphs 2.05, 7.02 and 8.01 which are supplemented herein.

2. ERECTION DETAILS

2.02 The 3 foot wide manholes are not standard in California. See Addendum G43.120.1 Paragraph 2.07, for cross braces for manholes 4 feet wide.

7. ERECTION OF FORMS AROUND CABLE OR OTHER STRUCTURES

7.02 Gas or electric pipe lines or conduit are not permitted to pass through telephone manholes. In general, inclusion of any foreign structures should be avoided. See Part 9 of Section G43.118.1.

8. CENTER RACK MANHOLES

8.01 These ducts unless otherwise specified should be placed with the top duct approximately 6 inches below the manhole ceiling.