

BLOCK AND HOUSE CABLE

GROUNDING - RUNNING GROUND WIRE

NOTES CONCERNING THIS ADDENDUM

This Addendum supplements Section G53.145. It prohibits the use of gas service pipes and limits the use of service pipes of private water systems for cable sheath grounds, protector grounds or signaling grounds. The instructions contained in this Addendum replace those of paragraphs 2.01 (b) and 2.01 (c) (1), of Section G53.145, which are hereby cancelled.

The cross reference, "See Addendum", should be placed at these paragraphs in Section G53.145.

2. SELECTION OF GROUND

2.01 (b) Public Gas System. Gas service pipes are not standard for cable sheath, protector or signaling grounds in this area and should never be used for such purposes.

(c) Private Water system.

(1) Do not use a private water system as a ground if a suitable public water system is available.