

ELECTROLYSIS DRAINAGE  
WIRE CONSTRUCTION  
INSTALLATION OF PROTECTIVE  
EQUIPMENT

NOTES CONCERNING THIS ADDENDUM

This addendum supplements Section G63.120.5 and has been issued to specify the location of fuses and switches.

The cross-reference, "See Addendum", should be marked in the main section to indicate the following:

- Paragraph 2.01 - Second sentence replaced.
- Paragraph 2.04 - Cancelled.
- Paragraph 3.01 - Replaced.

2. FUSES

2.01 Fuses should be located on a pole or other suitable support as near the manhole as practical when used with underground drainage wires.

3. ELECTROLYSIS SWITCHES

3.01 The standard electrolysis switch is housed in a waterproof metal case and should be located on a pole or other suitable support as near the manhole as practical when used with underground drainage wires. They shall be installed in accordance with the practices covering placing of electrolysis switch.