

**ELECTROLYSIS DRAINAGE**

**WIRE CONSTRUCTION**

**UNDERGROUND**

**NOTES CONCERNING THIS ADDENDUM**

This addendum supplements Section G63.120.6 and has been issued to delete a method which is not used here.

The illustrations in Paragraphs 3.01(a) and 3.01(b) should be marked "See Addendum."

**3. DRAINAGE WIRE CONSTRUCTION**

3.01 Delete that portion of the illustrations on Pages 2 and 3 which refers to Fuse or Electrolysis switch. Fuses and switches should be located on a pole or other suitable support as near the manhole as possible in accordance with other Practices in this series.