

## CABLE TERMINATING

### ORDERING AND INSTALLING CABLE FORMS

#### NOTES CONCERNING THIS ADDENDUM

This addendum supplements Section G71. 136 with additional instructions regarding the operation of closing cable openings under main frames where the openings are not designed to be sealed in the manner covered in Part 8 of the main section.

The cross reference, "See Addendum" should be written in Section G71. 136 following Paragraph 8. 02 to indicate the addition of new information.

#### 8. CLOSING CABLE OPENINGS UNDER MAIN FRAMES

8. 03 Where provision has not been made for steelwork and asbestos boards similar to those in Paragraphs 8. 01 and 8. 02, cable openings should be closed with waterplug cement as outlined in B. S. P. G55 series covering sealing ducts.

8. 04 The closures should always be replaced at night, if workmen are not on the job. Temporary closures may be used during the progress of the work.