

## CABLE OPENINGS

### 1. GENERAL

- 1.001 This addendum supplements Section H36.148, H54.302, Issue 2.
- 1.002 This addendum is issued to revise Paragraph 3.08 in Part 3.

### 3. CABLE HOLES

#### 3.08 *Sheathing for Walls and Partitions:*

Drawing ED-90006-01 provides for sheathing for cable holes in walls and partitions and also for floor openings in cable ducts. The sheathing for cable holes in fire resistive walls or partitions is based on fascia angles at both wall surfaces. In situations where the walls of the switchroom are exposed masonry, without plaster, the sheathing can be attached directly to the wall without the use of an angle iron frame. Fig. 4 in Issue 10 of Drawing ED-90006-01 illustrates this alternative method. Unused portion of opening in shaft walls is covered with steel plate furnished and installed by the Telephone Company.