

ELECTRIC WIRING AND EQUIPMENT

1. GENERAL

- 1.01 This addendum is issued to discuss the use of ornamental lamps.

2. ORNAMENTAL LAMPS

2.01 In Operators' Quarters or Lunch Rooms only, ornamental table lamps or floor lamps are permissible, provided they conform to the National Electrical Code and this Practice.

2.02 Shades on such lamps may be of fabric or parchment, provided they are securely mounted on wire or metal frames which hold them "clear" of the lamp bulb by at least three inches.

inches with top open for ventilation. Shades made of inflammable materials such as celluloid are prohibited, as are parchment shades finished with inflammable lacquers of the pyroxalin or nitro cellulose type.

2.03 Cords for such lamps must have not less than 1/32 inch rubber insulation; conductors must be #18 gauge, and must bear the approval label of the Underwriters Laboratories Inc. Cords with an outer jacket of rubber (Type POSJ or SJ) are preferred to cords with an outer braid of silk or cotton which usually frays and becomes easily ignitable.