

*L. W. C.
your file*

BELL SYSTEM PRACTICES
Buildings
Fire Protection

ADDENDUM H43-001
Issue A, 4-2-58
N. W. C. TEL. CO.
MINN. AREA

PROTECTIVE APPARATUS - GENERAL

1. GENERAL

1.01 This Addendum is issued to clarify procedures regarding location of fire protective equipment in small offices.

2. INSTALLATION OF PROTECTIVE APPARATUS

Note: The following paragraph replaces the one of like number in this Section H43.001.

2.02 The amount, type, and location of protective apparatus will be specified for each office by the Chief Engineer except for small offices requiring only one fire extinguisher and for unattended dial offices, in which case the District Plant Superintendent shall order the required extinguishers and locate them without instructions other than this Addendum. These shall be located so as to be easily seen and used, in the room with the telephone equipment.