

TABLE A-FEATURES											
EQUIPMENT		RAT- ING	LIST OR GROUP	QTY	EQUIPMENT OR CIRCUIT DATA				SD EQUIVALENT		
DESCRIPTION	REF NOTE				EQUIPMENT OR CIRCUIT	L/G OR FIG	WRG	APP	SCHEMATIC	FIG	OPT
ASSEMBLY, WIRING AND APPARATUS FOR ONE DISTRIBUTE POINT APPLIQUE UNIT. DA EFF:11/01/93 FE/RA:NONE		DA	1	1	T3H911-11	1			SD3H911-01	1	
REQUIRED IN ADDITION TO LIST 1 WHEN UNIT IS ORDERED FOR GROWTH APPLICATIONS AND IS SHOP MOUNTED, ISSUE 8 OR LATER OF THIS DRAWING. DA EFF:06/01/91 FE/RA:NONE		DA	TA	1							
END OF TABLE-A											

ENGINEERING NOTES

51. INFORMATION FURNISHED PER THIS DRAWING IS IN ACCORDANCE WITH AT&T PRACTICES- 820-651-150.

52. THIS DOCUMENT CONTAINS COMPLETE ENGINEERING INFORMATION FOR SUBJECT EQUIPMENT. JOB INFORMATION SHALL BE RECORDED BY LIST OR GROUP.

53. FOR MOUNTING PLATE DRILLING DATA NOT APPARENT IN STOCKLIST SEE TABLE B.



ISSUE NOTES				
LIST 'TA' READ 'A'.				
AT&T CL: NONE ORIG ISS: 04/23/76 NDD NBR: 3H001IH-68 WECCO CL: D				
DRAFT: JRP	ENGR: GLF	SUPV:	VAULT: 08/10/82	ISSUE: 7
IN TABLE A, LIST TA, REF TO 'AND IS SHOP MOUNTED', ADDED. LIST OF ASSOCIATED DRAWING TABLE CORRECTED.				
ORIG ISS: 04/23/76 CHANGE CLASS: B				
DRAFT: DJP	ENGR: GLF	SUPV:	VAULT: 01/16/85	ISSUE: 8
DRAWING CONVERTED FROM SEDBS TO MDS COMPUTER SYSTEMS.				
ORIG ISS: 04/23/76 CHANGE CLASS: D				
DRAFT: DJP	ENGR: GLF	SUPV:	CERTIFIED: 03/17/86	ISSUE: 9
IN SL ITEM 1140 COMCODE READ 814617080. ENGR NOTE 53 ADDED. DRAWING RATING READ 'STANDARD'.				
ORIG ISS: 04/23/76 CHANGE CLASS: M				
DRAFT: DSL	ENGR: GLF	SUPV:	CERTIFIED: 04/27/87	ISSUE: 10
IN SL ITEMS 1150, 1160 AND 1170 ADDED.				
ORIG ISS: 04/23/76 CHANGE CLASS: M				
DRAFT: DSL	ENGR: GLF	SUPV:	CERTIFIED: 12/09/87	ISSUE: 11
DISTRIBUTION CODE INVALID, READ 1T11. PER PROP CODE, CHG'D TO BT11. STAMPING RELOCATED ON REAR VIEW OF FIG 1. SL ITEMS 1020 AND 1100 LINED OUT, ITEMS 1021 AND 1101 ADDED. (PI 11.1, 11.2, 11.3).				
ORIG ISS: 04/23/76 CHANGE CLASS: MF				
DRAFT: PKK	ENGR: RJZ	SUPV:	CERTIFIED: 02/17/92	ISSUE: 12
SHEET B1, STAMP LOCATION ON REAR OF FIG. 1, CHANGED. TABLE A, LIST 1 AND TA RATING IS "DISCONTINUED AVAILABILITY".				
ORIG ISS: 04/23/76 CHANGE CLASS: MF				
DRAFT: JAT	ENGR: JAT	SUPV: RGM	CERTIFIED: 07/12/94	ISSUE: 13
IN SL, ITEM 1090 LINED OUT & 1091 ADDED & SHEET C1 FIG. A CHANGED PER. P.I. 13.1.				
ORIG ISS: 04/23/76 CHANGE CLASS: MF				
DRAFT: CRS	ENGR: CRS	SUPV:	CERTIFIED: 11/10/94	ISSUE: 14

SHEET INDEX											
SHT NBR	A1	THRU	A1	ISSUE	14						
SHT NBR	D1	THRU	D1	ISSUE	14						
SHT NBR	B1										
ISSUE	13										
SHT NBR	C1										
ISSUE	14										
SHT NBR											
ISSUE											
SHT NBR											
ISSUE											
SHT NBR											
ISSUE											
SHT NBR											
ISSUE											
SHT NBR											
ISSUE											
SHT NBR											
ISSUE											

J3H001EF-1

COPYRIGHT @ 1994 AT&T ALL RIGHTS RESERVED			
			BT11
3ESS SWITCHING EQUIPMENT MISCELLANEOUS FRAME DISTRIBUTE POINT APPLIQUE UNIT			
		DWG SIZE C2	ISSUE 14
AT&T	J3H001EF-1		SHEET A1 OF 4

CONVERSION TABLE	
INCH	MM
2"	50.8



J3H001EF-1

COPYRIGHT 1994 AT&T, ALL RIGHTS RESERVED		
DISTRIBUTE POINT APPLIQUE UNIT	DWG SIZE	ISSUE
	C2	13
AT&T	J3H001EF-1	SHEET B1

PRINTED IN U.S.A.

TABLE F					
FUSE REQUIREMENT					
ITEM	QTY	FUSE AMP CODE	BAT	POT	NET NAME
1	1	.75	A	48S	48A
2	1	.75	B	48S	48B

TABLE AB			
PD ASSIGNMENTS			
ITEM	CKT/UNIT	POINTS	REMARKS
1	4	A(0-3)	




FIG. A
ASSEMBLY CODE 13004

STOCKLIST								
ITEM NBR	LIST GROUP CODE	QTY PER CODE	PRODUCT IDENTIFIER	CODE	DESCRIPTION	REFERENCE POSITION	NOTE	
							SYM	NBR
1010	1	1	102824273	290A4J05	PLATE, MOUNTING E/W			
1020	1	8	100517320	13L	LAMP, RESISTANCE POS 3T48,3B54, POS 3T85,3B91, POS 3T107,3B113, POS 3T143,3B149			
1021	1	8	101306348	13L	LAMP RESISTANCE POS 3T48,3B54, POS 3T85,3B91, POS 3T107,3B113, POS 3T143,3B149			
1030	1	2	101644771	AK56	RELAY POS 65,125			
1040	1	2	100734862	D5A	STRIP, TERMINAL E/W POS 161,177			12
1041	1	2	840028658		GUIDE, WIRE			
1050	1	4	100734003	278A	STRIP, TERMINAL (3004) E/W POS 40,77,99,135			
1060	1	4	997494406	KS19152L2	RESISTOR 680 OHM (R10),(R11), (R12),(R13)			
1070	1	4	997497144	KS19151L1	RESISTOR 1300 OHM (R20),(R21), (R22),(R23)			
1080	1	8	100043496	535CE	CAPACITOR .511 UF (C10),(C11), (C12),(C13), (C20),(C21), (C22),(C23)			
1090	1	4	100174226	458A	DIODE (CR0),(CR1), (CR2),(CR3)			
1091	1	4	405199688	WP90015L4	DIODE, SWITCHING (CR0),(CR1), (CR2),(CR3)			
1100	1	4	840047534		SCREW, PAN HEAD SELF TAPPING .216-24 X 5/8 STEEL 289A FINISH			*/
1101	1	4	840026835		SCREW, TTF SLOTTED HEX, WASHER HD .216-24 X 5/8 TAPPING TYPE (SWAGE FORM) STEEL ZINC PLATE 289A FINISH			*/
1110	1	2	100203397	70H	FUSE .75 AMP			W*
1120	1	2	401922117	KS14174L8	PIN, DESIGNATION NYLON BROWN			W*
1130	1	1	401675368	KS21336L1	WIRE 28GA SOLID G 40 FT.			*/
1140	1	1	843745373		WIRE BH2 24GA BK/R-BK 20 FT.			*/
1150	1	12	814139150	P41C915	SCREW, PAN HEAD SELF TAPPING .138-20 X 5/8 STEEL 289A FINISH			
1160	1	8	801814120	F181412	SCREW, MACHINE			
1170	1	4	801398074	F139807	SCREW, FLAT HEAD MACHINE .138-32 X 11/32			
***** END OF STOCKLIST *****								

SHOP
IN
ST

MANUFACTURING NOTES

1. X PARTS REQUIRED FOR INSTALLATION.

X/ PARTS REQUIRED FOR MANUFACTURE WHEN EQUIPMENT IS SHOP MOUNTED OR BY THE INSTALLER WHEN THE EQUIPMENT IS TO BE FIELD MOUNTED.

* PARTS THAT ARE TO BE SHIPPED ATTACHED TO OR ENCLOSED IN THE SAME CONTAINER WITH THE ASSOCIATED ASSEMBLED ITEM.

*/ PARTS (A) REQUIRED FOR MANUFACTURE WHEN EQUIPMENT INVOLVED IS SHOP MOUNTED OR (B) TO BE SHIPPED ATTACHED TO, OR ENCLOSED IN THE SAME CONTAINER WITH THE ASSOCIATED ASSEMBLED ITEM WHEN FIELD MOUNTED.

() INDICATES DESIGNATIONS TO BE STAMPED IN ACCORDANCE WITH JOB INFORMATION.

{ } INDICATES DESIGNATIONS SHOWN FOR INFORMATION ONLY AND ARE NOT TO BE STAMPED.

< > INDICATES DESIGNATIONS AND/OR INFORMATION PROVIDED IN ACCORDANCE WITH OTHER INFORMATION.

"W" PARTS ASSEMBLED AT THE SAME TIME THE EQUIPMENT IS MOUNTED.

"W*" PARTS TO BE (A) SHOP ASSEMBLED, BUT WHICH CANNOT BE ASSEMBLED UNTIL THE ASSOCIATED EQUIPMENT IS BEING MOUNTED, OR (B) SHIPPED ATTACHED TO, OR ENCLOSED IN THE SAME CONTAINER WITH THE ASSOCIATED EQUIPMENT WHEN FIELD MOUNTED.

"S" PARTS NOT ASSEMBLED, SHIPPED SEPARATELY.

A/R AS REQUIRED.

"B" PARTIAL ASSEMBLIES ON OTHER DRAWINGS WITH STOCKLISTS.

12. DISCARD WIRE GUIDE PROVIDED WITH D5A T.S. AND USE WIRE GUIDE PROVIDED IN STOCKLIST.

13. THIS DRAWING CONTAINS BOTH U.S. CUSTOMARY (INCH, ETC) AND SI (METRIC) DIMENSIONS.

X X

COPYRIGHT © 1994 AT&T
ALL RIGHTS RESERVED

BT11

3ESS SWITCHING EQUIPMENT
MISCELLANEOUS FRAME
DISTRIBUTE POINT APPLIQUE UNIT

DWG SIZE C2 ISSUE 14

J3H001EF-1

AT&T

J3H001EF-1

SHEET D1 OF 4

PRINTED IN U.S.A.