

TABLE A-FEATURES											
EQUIPMENT		RAT- ING	LIST OR GROUP	QTY	EQUIPMENT OR CIRCUIT DATA				SD EQUIVALENT		
DESCRIPTION	REF NOTE				EQUIPMENT OR CIRCUIT	L/G OR FIG	WRG	APP	SCHEMATIC	FIG	OPT
ASSEMBLY, WIRING AND EQUIPMENT FOR ONE +48V FUSE PANEL (FPPF). DA EFP:07/05/95 FE/RA:NONE	54	DA	1	1	SD5D083-01	1					
EQUIPMENT REQUIRED IN ADDITION TO LIST 1 TO PROVIDE CABINET FUSE ALARM LED CAPABILITY. (SEE NOTE 53). DA EFP:07/05/95 FE/RA:NONE		DA	2	1	SD5D083-01	2					
END OF TABLE-A											

ENGINEERING NOTES

51. INFORMATION FURNISHED PER THIS DRAWING IS IN ACCORDANCE WITH AT&T PRACTICES NONE.

52. THIS DOCUMENT CONTAINS COMPLETE ENGINEERING INFORMATION FOR THE SUBJECT EQUIPMENT. JOB INFORMATION SHALL BE RECORDED BY LIST OR GROUP.

53. ONE LIST 2 MUST BE PROVIDED FOR EACH CABINET WHICH PROVIDES THIS UNIT.

54. 'THE COMCODES SHOWN IN THE STOCKLIST IDENTIFICATION FIELD REFERENCED BY THIS NOTE ARE NOT THE INDIVIDUAL OR SINGULAR COMCODE FOR THE PART DESCRIBED BUT ARE THE FACTORY'S ORDERING COMCODE. TABLE JJ CONTAINS THE FACTORY'S ORDERING COMCODE FOR THE DESCRIBED PART AND THE EQUIVALENT SINGULAR/INDIVIDUAL COMCODE THAT MAY BE REQUIRED BY AN INSTALLER, CUSTOMER, REGIONAL LINE ENGINEER, OR A CLASS A CHANGE NOTICE'.



ISSUE NOTES				
ORIG ISS: 08/23/84 NDD NBR: 5D003IH-38 CHANGE CLASS:				
DRAFT: DJP	ENGR: EDH	SUPV: JFM	VAULT: 08/23/84	ISSUE: 1
* DRAWING CONVERTED FROM SEDBS TO MDS COMPUTER SYSTEMS. * * THIS IS A MACHINE COPY OF THE LATEST SEDBS CERTIFIED ISSUE * * AND MAY CONTAIN MINOR DIFFERENCES. THE TABLE OF ASSOCIATED * * DRAWINGS WAS ELIMINATED DURING MIGRATION TO ASSIST THE * * SCRUBBING OF PROPRIETARY INFORMATION. *				
LIST OF ASSOCIATED DRAWING TABLE CORRECTED. NOTE 12 REMOVED. NOTE 13 AND SL ITEMS 1012 THRU 1018 ADDED.				
ORIG ISS: 08/23/84 CHANGE CLASS: D				
DRAFT: DJP	ENGR: EDH	SUPV:	CERTIFIED: 01/29/86	ISSUE: 2
NOTE 54 & TABLE JJ ADDED. SL ITEM 1010 READ 100010487. REF TO NOTE 54 ADDED TO LIST 1. REF TO NOTE 13 ADDED TO SL ITEM 1010.				
ORIG ISS: 08/23/84 CHANGE CLASS: MF				
DRAFT: RJW	ENGR: RJW	SUPV:	CERTIFIED: 02/15/91	ISSUE: 3
LISTS 1 AND 2 READ STANDARD.				
ORIG ISS: 08/23/84 CHANGE CLASS: M				
DRAFT: JJR	ENGR: JJR	SUPV: GJM	CERTIFIED: 07/05/95	ISSUE: 4

SHEET INDEX											
SHT NBR	A1 THRU A1										ISSUE 4
ISSUE											
SHT NBR	D1 THRU D1										ISSUE 4
ISSUE											
SHT NBR	B1										
ISSUE	1										
SHT NBR	C1										
ISSUE	1										
SHT NBR											
ISSUE											
SHT NBR											
ISSUE											
SHT NBR											
ISSUE											
SHT NBR											
ISSUE											
SHT NBR											
ISSUE											
SHT NBR											
ISSUE											
SHT NBR											
ISSUE											

TABLE OF CONTENTS	
DESCRIPTION	SHT
SHEET INDEX	A1
ISSUE NOTES	A1
ENGINEERING-NOTES	A1
TABLE A	A1
B SECTION GRAPHICS	B1
C SECTION GRAPHICS	C1
MANUFACTURING NOTES	D1
STOCKLIST	D1
MISCELLANEOUS TABLES	D1

AT&T - PROPRIETARY USE PURSUANT TO COMPANY INSTRUCTIONS		
BT13		
5ESS SWITCHING EQUIPMENT SPECIFICATION FOR +48V FUSE PANEL (FPPF)		
DWG SIZE C2	ISSUE 4	
AT&T	J5D003AJ-1	SHEET A1 OF 4

J5D003AJ-1



DETAIL A

SEE PROPRIETARY NOTICE ON SHEET ONE

J5D003AJ-1

SHEET INDEX		ISSUE												
SH NO.														
ISSUE														
SH NO.														
ISSUE	1													
SH NO.	C1													

FUSE PANEL		DWG SIZE	ISSUE
		C2	1
AT&T TECHNOLOGIES, INC.	J5D003AJ-1	PRINTED IN U.S.A.	SHEET C1

51J5D003AJ(C1).PRT

STOCKLIST								
ITEM NBR	LIST GROUP CODE	QTY PER CODE	PRODUCT IDENTIFIER	CODE	DESCRIPTION	REFERENCE POSITION	NOTE	
							SYM	NBR
1000	1	1	845080951		PLATE, MOUNTING			
1010	1	6	845048008		BLOCK, FUSE TACKLE POS 01-033,057,081, POS 01-105,129,153			13
1012	1	12	814320487	P43B048	SCREW, PAN HEAD SELF TAPPING .138-20 X 1/2 STEEL 289A FINISH			13
1014	1	24	824557003	P45N700	SCREW, PAN HEAD TAPPING .086-32 X 1/2 STEEL 289A FINISH			13
1016	1	48	811166677	F11F667	ASSEMBLY, FUSE CAP			13
1018	1	6	811224922	F12B492	COVER			13
1020	1	4	813320231	F33B023	BUSBAR, ALARM TERMINAL			
1030	1	2	813320538	F33B053	BUSBAR, BATTERY			
1040	1	4	843048307		INSULATOR			
1050	1	4	843048257		TERMINAL, BUS GROUND POS 01-041,073, POS 01-113,145			
1060	2	1	100734003	278A	STRIP, TERMINAL POS 01-171			
1070	2	2	400769352	KS20289L6C	RESISTOR 5110 OHM			
1080	2	2	100174242	458C	DIODE			
1090	1	4	840026835		SCREW, TTF SLOTTED HEX, WASHER HD .216-24 X 5/8 TAPPING TYPE (SWAGE FORM) STEEL ZINC PLATE 289A FINISH			*/
***** END OF STOCKLIST *****								

TABLE JJ

TABLE JJ STOCKLIST ORDERING COMCODES TO INDIVIDUAL/SINGULAR COMCODES CROSS REFERENCE		
STOCKLIST ORDERING COMCODE	INDIVIDUAL/SINGULAR COMCODE	COMMENTS
845048008	100010487	WHEN THE SINGULAR COMCODE, 100010487, IS ORDERED, ALL PIECEPARTS INDICATED IN THE FIRST COLUMN WILL BE SHIPPED AS A COMPLETE KIT.
814320487		
824557003		
811166677		
811224922		

S
H
O
P

I
N
S
T

MANUFACTURING NOTES

1. X PARTS REQUIRED FOR INSTALLATION.

X/ PARTS REQUIRED FOR MANUFACTURE WHEN EQUIPMENT IS SHOP MOUNTED OR BY THE INSTALLER WHEN THE EQUIPMENT IS TO BE FIELD MOUNTED.

* PARTS THAT ARE TO BE SHIPPED ATTACHED TO OR ENCLOSED IN THE SAME CONTAINER WITH THE ASSOCIATED ASSEMBLED ITEM.

*/ PARTS (A) REQUIRED FOR MANUFACTURE WHEN EQUIPMENT INVOLVED IS SHOP MOUNTED OR (B) TO BE SHIPPED ATTACHED TO, OR ENCLOSED IN THE SAME CONTAINER WITH THE ASSOCIATED ASSEMBLED ITEM WHEN FIELD MOUNTED.

() INDICATES DESIGNATIONS TO BE STAMPED IN ACCORDANCE WITH JOB INFORMATION.

{ } INDICATES DESIGNATIONS SHOWN FOR INFORMATION ONLY AND ARE NOT TO BE STAMPED.

< > INDICATES DESIGNATIONS AND/OR INFORMATION PROVIDED IN ACCORDANCE WITH OTHER INFORMATION.

"W" PARTS ASSEMBLED AT THE SAME TIME THE EQUIPMENT IS MOUNTED.

"W*" PARTS TO BE (A) SHOP ASSEMBLED, BUT WHICH CANNOT BE ASSEMBLED UNTIL THE ASSOCIATED EQUIPMENT IS BEING MOUNTED, OR (B) SHIPPED ATTACHED TO, OR ENCLOSED IN THE SAME CONTAINER WITH THE ASSOCIATED EQUIPMENT WHEN FIELD MOUNTED.

"S" PARTS NOT ASSEMBLED, SHIPPED SEPARATELY.

A/R AS REQUIRED.

"B" PARTIAL ASSEMBLIES ON OTHER DRAWINGS WITH STOCKLISTS.

12. UNASSIGNED.

13. EQUIPMENT REQUIRED FOR ASSEMBLY OF 23A FUSE BLOCKS.

X X

SEE PROPRIETARY NOTICE ON SHEET ONE

BT13

5ESS SWITCHING EQUIPMENT
SPECIFICATION FOR
+48V FUSE PANEL
(PPP)DWG SIZE
C2ISSUE
4

J5D003AJ-1

AT&T

J5D003AJ-1

SHEET D1
OF 4

PRINTED IN U.S.A.