



Avaya Communication Server 1000

Communication Server 1000
Cabinet System Evaluation

Avaya Data Solutions
Document Date: November 2010
Document Number: NN43011-301
Document Version: 05.02

© 2010 Avaya Inc.
All Rights Reserved.

Notices

While reasonable efforts have been made to ensure that the information in this document is complete and accurate at the time of printing, Avaya assumes no liability for any errors. Avaya reserves the right to make changes and corrections to the information in this document without the obligation to notify any person or organization of such changes.

Documentation disclaimer

Avaya shall not be responsible for any modifications, additions, or deletions to the original published version of this documentation unless such modifications, additions, or deletions were performed by Avaya. End User agree to indemnify and hold harmless Avaya, Avaya's agents, servants and employees against all claims, lawsuits, demands and judgments arising out of, or in connection with, subsequent modifications, additions or deletions to this documentation, to the extent made by End User.

Link disclaimer

Avaya is not responsible for the contents or reliability of any linked Web sites referenced within this site or documentation(s) provided by Avaya. Avaya is not responsible for the accuracy of any information, statement or content provided on these sites and does not necessarily endorse the products, services, or information described or offered within them. Avaya does not guarantee that these links will work all the time and has no control over the availability of the linked pages.

Warranty

Avaya provides a limited warranty on this product. Refer to your sales agreement to establish the terms of the limited warranty. In addition, Avaya's standard warranty language, as well as information regarding support for this product, while under warranty, is available to Avaya customers and other parties through the Avaya Support Web site: <http://www.avaya.com/support>

Please note that if you acquired the product from an authorized reseller, the warranty is provided to you by said reseller and not by Avaya.

Licenses

THE SOFTWARE LICENSE TERMS AVAILABLE ON THE AVAYA WEBSITE, [HTTP://SUPPORT.AVAYA.COM/LICENSEINFO/](http://SUPPORT.AVAYA.COM/LICENSEINFO/) ARE APPLICABLE TO ANYONE WHO DOWNLOADS, USES AND/OR INSTALLS AVAYA SOFTWARE, PURCHASED FROM AVAYA INC., ANY AVAYA AFFILIATE, OR AN AUTHORIZED AVAYA RESELLER (AS APPLICABLE) UNDER A COMMERCIAL AGREEMENT WITH AVAYA OR AN AUTHORIZED AVAYA RESELLER. UNLESS OTHERWISE AGREED TO BY AVAYA IN WRITING, AVAYA DOES NOT EXTEND THIS LICENSE IF THE SOFTWARE WAS OBTAINED FROM ANYONE OTHER THAN AVAYA, AN AVAYA AFFILIATE OR AN AVAYA AUTHORIZED RESELLER, AND AVAYA RESERVES THE RIGHT TO TAKE LEGAL ACTION AGAINST YOU AND ANYONE ELSE USING OR SELLING THE SOFTWARE WITHOUT A LICENSE. BY INSTALLING, DOWNLOADING OR USING THE SOFTWARE, OR AUTHORIZING OTHERS TO DO SO, YOU, ON BEHALF OF YOURSELF AND THE ENTITY FOR WHOM YOU ARE INSTALLING, DOWNLOADING OR USING THE SOFTWARE (HEREINAFTER REFERRED TO INTERCHANGEABLY AS "YOU" AND "END USER"), AGREE TO THESE TERMS AND CONDITIONS AND CREATE A BINDING CONTRACT BETWEEN YOU AND AVAYA INC. OR THE APPLICABLE AVAYA AFFILIATE ("AVAYA").

Copyright

Except where expressly stated otherwise, no use should be made of the Documentation(s) and Product(s) provided by Avaya. All content in this documentation(s) and the product(s) provided by Avaya including the selection, arrangement and design of the content is owned either by Avaya or its licensors and is protected by copyright and other intellectual property laws including the sui generis rights relating to the protection of databases. You may not modify, copy, reproduce, republish, upload, post, transmit or distribute in any way any content, in whole or in part, including any code and software. Unauthorized reproduction, transmission, dissemination, storage, and or use without the express written consent of Avaya can be a criminal, as well as a civil offense under the applicable law.

Third Party Components

Certain software programs or portions thereof included in the Product may contain software distributed under third party agreements ("Third Party Components"), which may contain terms that expand or limit rights to use certain portions of the Product ("Third Party Terms"). Information regarding distributed Linux OS source code (for those Products that have distributed the Linux OS source code), and identifying the copyright holders of the Third Party Components and the Third Party Terms that apply to them is available on the Avaya Support Web site: <http://support.avaya.com/Copyright>.

Trademarks

The trademarks, logos and service marks ("Marks") displayed in this site, the documentation(s) and product(s) provided by Avaya are the registered or unregistered Marks of Avaya, its affiliates, or other third parties. Users are not permitted to use such Marks without prior written consent from Avaya or such third party which may own the Mark. Nothing contained in this site, the documentation(s) and product(s) should be construed as granting, by implication, estoppel, or otherwise, any license or right in and to the Marks without the express written permission of Avaya or the applicable third party. Avaya is a registered trademark of Avaya Inc. All non-Avaya trademarks are the property of their respective owners.

Downloading documents

For the most current versions of documentation, see the Avaya Support. Web site: <http://www.avaya.com/support>

Contact Avaya Support

Avaya provides a telephone number for you to use to report problems or to ask questions about your product. The support telephone number is 1-800-242-2121 in the United States. For additional support telephone numbers, see the Avaya Web site: <http://www.avaya.com/support>

Table of Contents

AVAYA COMMUNICATION SERVER 1000 CABINET/ MERIDIAN 1 PBX 11C CABINET SYSTEM EVALUATION..... 4

 LOCATION PROFILE 6

 CS 1000 CABINET SAMPLE SITE LAYOUT 8

SYSTEM AND SITE REQUIREMENTS CHECKLIST 15

 EQUIPMENT ROOM ENVIRONMENT 15

 POWER AND GROUNDING 17

 AC POWER & GROUND WORKSHEET 20

 POWER & GROUNDING FOR SYSTEMS WITH DC POWER..... 26

 BATTERY INSTALLATION WORKSHEET..... 29

 CABINET INSTALLATION 30

 CABLING INSTALLATION 31

 SYSTEM OPERATION 34

 SYSTEM SOFTWARE 36

 NETWORKING PARAMETERS FOR VOIP 38

Avaya Communication Server 1000 Cabinet/ Meridian 1 PBX 11C Cabinet System Evaluation

for

SUMMARY:

A system evaluation of the _____(Customer)
Avaya Communication Server 1000 Cabinet solution in
_____(City) was requested by
_____(Name) of
_____(Company). The evaluation was performed
on _____(Date). The nature of the evaluation was to determine if the
Avaya CS 1000 Cabinet was installed per manufacturing specifications and
Product Bulletin requirements.

DISTRIBUTION:

EVALUATED BY:

DATE:

A stand-alone IP Trunk (ITG Trunk) configuration is the only IP application supported on the Meridian 1 Option 11C platform in Communication Server 1000 Release 5.5 or earlier.

Systems described within this document that are configured with IP Phones or Signaling Servers using Communication Server 1000 Release 4.5 and want to upgrade to Communication Server 1000 Release 7.5 must be upgraded to Avaya Communication Server 1000E with a Common Processor Pentium Mobile (CP PM) call processor. For migrations to Communication Server Release 7.5, refer to:

- *Avaya Communication Server 1000E Upgrade - Hardware Upgrade Procedures (NN43041-464)*
- *Avaya Communication Server 1000E Upgrade - Software Upgrades (NN43041-458)*

Location Profile

Site Information:


Audit Engineer:	_____	Evaluation Date:	_____
Distributor:	_____	Customer:	_____
Address:	_____	Address:	_____
Contact:	_____	Site Telephone:	_____
Telephone:	_____	Attendees:	_____
Email:	_____		_____

System Information:

System Serial Number XXXXX

	Type/Platform	Software Release	Ports
PBX	<u>CS 1000 Cabinet</u>	<u>XX21/X.00</u>	<u>XXX</u>
TM	_____	_____	_____
Call Center Server	_____	_____	_____
Call Pilot IPE	_____	_____	_____
VGMC	_____	_____	_____
Signaling Server (ISP 1100, CP PM, COTS)	_____	_____	_____

CS 1000 Cabinet Sample Site Layout



FINDINGS AND RECOMMENDATIONS

Introduction:

The evaluation of this CS 1000 System Cabinet, located _____
 _____ was requested by _____. The request was initiated because
 _____.

The evaluation was performed on (date) _____ and covered the areas of Equipment Room Environment, Maintenance and Technician Area Environment, Power and Grounding, System Power and Ground Connections, Cabinet Installation, Cabling Installation, System Operation, System Software, and Network Parameters for VoIP. _____ (name of company representative) was the main contact person during the evaluation process. All questions that pertain to this report may be directed to _____.

DISCREPANCIES AND RECOMMENDATIONS:

EQUIPMENT ROOM ENVIRONMENT

<p>Item #</p> <p>Findings:</p> <p>Recommendation:</p>	
--	--

MAINTENANCE AND TECHNICIAN AREA ENVIRONMENT

Item #	
Findings:	
Recommendation:	

POWER AND GROUNDING

Item #	
Findings:	
Recommendation:	

SYSTEM POWER AND GROUND CONNECTIONS

Item #	
Findings:	
Recommendation:	

POWER AND GROUNDING FOR SYSTEMS WITH DC POWER

Item #	
Findings:	
Recommendation:	

BATTERY INSTALLATION

Item #	
Findings:	
Recommendation:	

CABINET INSTALLATION

Item # Findings: Recommendation:	
---	--

CABLING INSTALLATION

Item # Findings: Recommendation:	
---	--

SYSTEM OPERATION

Item #	
Findings:	
Recommendation:	

SYSTEM SOFTWARE

Item #	
Findings:	
Recommendation:	

NETWORK PARAMETERS FOR VoIP

<p>Item #</p> <p>Findings:</p> <p>Recommendation:</p>	
--	--

CONCLUSION

NOTE: *This report is based on checklist items contained in this document. The checklist item under each subheading is answered with a “Y” or “N”, signifying that it either complies or does not comply with Avaya specifications. An “N/A” means that the checklist question does not apply in this instance. The specifications are based on Avaya Practices, Product Bulletins, Product Advisories, and General Release Bulletins. Each checklist item is given a weight. The item may be deemed as “Critical, Major, Minor, or Recommended” in nature. A system evaluation is found to be “non-compliant” when one “Critical” or two “Major” discrepancies have been identified. Checklist weighting is not given to Applications products questions. The aim of an evaluation is to ensure installation completeness, optimize system performance/reliability, and provide a safe environment for personnel..*

Further Comments:

Equipment Room Environment

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Planning and Engineering (NN43011-220)

Meridian 1 Small System Installation and Commissioning (NN43011-310)

- 11. Equipment is not exposed to excessive vibration. [Major]
- 12. Switch room door has a lock installed. [Minor]
- 13. No tripping or safety hazards exist in the equipment room. [Major]
- 14. Lighting illumination is 50 to 75 foot candles measured 76 cm (30 in.) above the equipment room floor. [Recommendation]
- 15. Equipment room is protected from receiving direct sunlight. Direct sunlight is prevented from shining on electronic hardware, especially disk drives. [Major]
- 16. Adequate floor space has been made available to install equipment racks, patch panels, power systems (UPS) etc. [Major]
- 17. RS-232 terminal/communications devices should not exceed the 50 foot cable length limit unless line drivers are utilized. [Major]
- 18. The storage room for spare parts is secure. [Recommendation]
- 19. If it is not possible that the site maintain the environment of the storage area exactly the same as the environment of the operating equipment, stored materials are allowed time to adjust to the equipment room environment before using them. [Major]
- 20. The storage area is dust-free and away from high humidity and machinery such as electric motors of transformers. [Major]
- 21. Cross-connect terminal or other equipment that could cause debris to fall into the ventilation slots of the system is not located above the cabinet. [Critical]
- 22. Circuit cards which are not in use are stored in a protective antistatic bag. The storage area is dust-free and away from high humidity and machinery such as electric motors or transformers. [Major]
- 23. Cabinet covers are installed. [Major]

Maintenance and Technician Area Environment

- 24. A locking cabinet or storage area is in place for backup disks [Recommendation]

Equipment Room Environment

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Planning and Engineering (NN43011-220)

Meridian 1 Small System Installation and Commissioning (NN43011-310)

- 25. The area contains a table or desk terminal, printer, or equivalent device [Recommendation]
- 26. Maintenance workstation is equipped with a/an: [Major]
 - dial-up modem or connected to the network;
 - web browser;
 - operational maintenance telephone.
- 27. Observations/Comments

Power and Grounding

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310)

National Electrical Code (NEC) Article 110, 210, 250

Avaya Communication Server 1000 Cabinet System AC Service Panel

- 1. In the AC-powered version of the Cabinet system, a dedicated AC service panel is used. Equipment that is not related to the PBX system is not connected to this panel. All electrical devices such as lighting, fans, motors, and air conditioning equipment are not contained in the PBX dedicated AC service panel.

Power and Grounding

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310)

National Electrical Code (NEC) Article 110, 210, 250

12. Power from each receptacle meets the input requirements of the Cabinet system power supply listed in the following table:

AC input requirements for each NTDK70 cabinet power supply		y/n
Voltage	Maximum rated input voltage 100-240 Volts RMS, single phase	
Frequency	50-60 Hz	
Power (I/P max)	750 VA minimum	
Receptacle Type	NEMA 5-15R for 120 Volt, 15 Amp supply NEMA 6-15R for 208/240 Volt, 15 Amp supply	

Location of power receptacles

NOTE: The maximum distance between a power receptacle and the system cabinet is met in relation to the length of the power cord.

- In North America, the power cord is 9 ft 10 in. (3000 mm).
- Outside North America, the power cord is 8 ft 2 in. (2490 mm).

13. Observations/Comments

AC Power & Ground Worksheet

AC Service Panel Measurements

Note: If a portable UPS system is used, measurements will only be taken on the input/output voltage and the neutral-ground voltage. Percent of load must also be notated

Voltage Measurements:

	AC	MIN -MAX
	_____	_____
Between neutral and phase A	_____ volts	105v 125v
Between neutral and phase B	_____ volts	105v 125v
Between neutral and phase C	_____ volts	105v 125v
Between ground and phase A	_____ volts	105v 125v
Between ground and phase B	_____ volts	105v 125v
Between ground and phase C	_____ volts	105v 125v
Between phase A and phase B	_____ volts	180v 250v
Between phase A and phase C	_____ volts	180v 250v
Between phase B and phase C	_____ volts	180v 250v
Between neutral and ground (ACEG)	_____ Vrms	0.0v 0.5Vrms
UPS percent of load:	_____	
UPS input voltage:	_____	
UPS output voltage:	_____	
Current Measurements:	AC	MAX
	_____	_____
Neutral conductor amps	_____ amps	See Note 1

Voltage Measurements:	AC	MIN -MAX
Ground conductor amps (IG or ACEG)	_____ amps	0.5 amps
Phase A amps	_____ amps	
Phase B amps	_____ amps	
Phase C amps	_____ amps	

Note 1: The neutral current should never exceed the current in any single-phase leg.

A licensed electrician must take AC service panel measurements.

Voltage and current values must comply with technical publications.

Voltage between neutral and ground could signify poor or loose connections or non-continuous grounding.

Current flow in the grounding conductor may indicate that the neutral has been used for equipment grounding.

If currents are balanced in a three phase system and there is significant neutral current, then harmonics are present. Harmonics can deteriorate transformers over time by over heating their internal wiring. Solution: Use transformers specifically designed for harmonic loading (k-factor-rated).

System Power and Ground Connections

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310) National Electrical Code (NEC) Article 250

1. The Signaling Server power cord is plugged into the rack's AC receptacle and the rack's AC receptacle is grounded to its dedicated electrical panel. [Major]

2. In an installation where a dedicated panel cannot provide optimal conditions, a load isolation transformer or load isolation transformer-based UPS/Line conditioner with the following characteristics is used:

[Major]

- 120/208/240 V AC input, over-current protected at primary
 - 120/208/240 V AC available at secondary outputs, each circuit breaker protected
 - primary and secondary windings are completely isolated from one another
 - it is approved for use locally as a stand-alone user product (CSA, UL, or other locally recognized clear markings)
 - it is capable of providing power to all CS 1000 components operating at the same time at full load
 - it is electrostatically shielded to minimize ELF fields
-

3. The method of grounding used for CS 1000 Cabinet depends on whether the same service panel powers all cabinets. This installation uses one of the following grounding scenarios:

Cabinet system with one or more cabinets powered by the same service panel:

For each system cabinet, a #6 AWG (#40 Metric Wire Gauge) ground wire is connected from the cabinet to the NTBK80 grounding block. The grounding block is connected to a ground source (the ground bus in the AC power service panel).

Cabinet system with more than one cabinet, powered by different service panels:

For each cabinet, a #6 AWG (#40 Metric Wire Gauge) ground wire is connected from the cabinet to the NTBK80 grounding block. If any cabinet cannot be powered from the same service panel, it is ground separately from the other cabinet back to the service panel that supplies it.

Note 1: A separately grounded cabinet is grounded the same as a single-cabinet system.

Note 2: In the UK, you can connect the grounding wire from the cabinet to an NTBK80 grounding block or through a Krone Test Jack Frame.

System Power and Ground Connections

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310) National Electrical Code (NEC) Article 250

4. Grounding multiple pieces of equipment in a rack/equipment

Cabinet:

Each piece of equipment in a rack/equipment cabinet is grounded. If a piece of equipment does not have a ground lug, then the whole rack/equipment cabinet is grounded.

5. The installation meets the specific grounding requirements for the area:
[Major]

Germany	#8 AWG (10 mm ²) green/yellow wire
North America; other areas in Europe	Not smaller than #6 AWG (16 mm ²) at any point
UK	Two green/yellow wires no thinner than two 10 mm ²

6. A system ground conductor, sized at a minimum of a #6 AWG stranded, insulated wire is installed from the cabinet ground bus to the ACEG bus in the AC panel. Where UPS systems are employed, a #6 AWG wire can be installed from the cabinet ground bus to the grounded metallic case of the UPS using a ground lug. [Critical if missing; Major if undersized].

7. A #6 AWG insulated, stranded conductor is installed between each CS 1000 cabinet ground lug and the cabinet ground bus. [Major]

8. All grounding conductors are clearly identified/labeled. [Minor]

9. Ground connections are tagged with a clear message such as "CRITICAL CONNECTION: DO NOT REMOVE OR DISCONNECT. [Minor]

10. No telecommunications ground bus of the CS 1000 is connected to untested horizontal structural steel, water pipes, or other unreliable ground paths. [Major]

Note: The SPG conductor from the CS 1000 Cabinet System is not connected to structural steel members or electrical conduit. This conductor is not tied to a ground source or grounded electrode that is not hard-wired to the building reference conductor.

System Power and Ground Connections

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310) National Electrical Code (NEC) Article 250

- 11. The cabinet ground bus is mounted near the CS 1000 cabinets. [Major]
- 12. CSUs (Channel Service Units) are connected to reserve power (UPS) or are span powered. [Major]
- 13. Ground conductors are insulated, permanent and continuous (not spliced). [Major]
- 14. All terminations are easily visible and accessible for maintenance purposes. [Major]
- 15. The impedance of the link between the ground post of the system cabinets and the SPG to which they are connected is less than 0.25 ohms.
- 16. For systems equipped with Expansion Cabinets, a separate receptacle for each cabinet is provided. Each receptacle is powered from separate branch circuits in the same service panel.
- 17. When installed on the wall, receptacles are installed within reach of the chassis or cabinet power cords.
- 18. The ground prong of each receptacle is connected by an insulated conductor to the system SPG.
- 19. If the transformer does not have an isolated secondary ground lug, the chassis ground lug of the transformer is used as the SPG.
- 20. If the transformer does not have a pluggable cord, the transformer is hardwired to an electrical panel. All wires (including grounds) are routed through a single conduit.
- 21. All ground wires are run through the same conduit as the phase conductors that serve the equipment.

Ancillary Equipment Power

- 22. Power for the ancillary equipment in the switch room is
 - powered from the same panel or transformer as the PBX
 - grounded to the same panel or transformer as the PBX
 - labeled at the panel to prevent interruption that is not authorized
 - not be controlled by a switch between the breaker and the equipment

System Power and Ground Connections

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310) National Electrical Code (NEC) Article 250

23. Service receptacles for AC-powered PBX System and related equipment are:
- rated for 120 or 240 V, 15 or 20A, 50-60 Hz, 3-pole, 3-wire, grounded
 - grounded to the same location so as to form a SPG.

Other items

24. QUA6 Power Failure Transfer Units (PFTU) are available to transfer trunk lines during a power or system failure. [Recommendation]

Note: The appropriate AC power cord kit is used for the installation as listed in the following table. (These cords connect a CS 1000 System Cabinet to a commercial AC power source.)

Country / Region	AC Power Cord	Voltage Rating	Current Rating	Plug Type
North America	A0379412	250 V	10 A	NEMA 6-15P
Argentina	A0814961	250 V	10 A	IRAM 2073
North America	NTTK14	125 V	13 A	NEMA 5-15P
Australia/ New Zealand	NTTK15	250 V	10 A	AS3112
Europe	NTTK16	250 V	10 A	CEE(7)VII
Switzerland	NTTK17	250 V	10 A	SEV 1011
UK/Ireland	NTTK18	250 V	10 A	BS1363
Denmark	NTTK22	250 V	10 A	AFSNIT

26. Observations/Comments

Power & Grounding for Systems with DC Power

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310) National Electrical Code (NEC) Article 300

1. Each cabinet in a CS 1000 Cabinet system powered solely from a DC source is equipped with an NTDK72 DC power supply and an NTAK28 Junction Box.
2. The input terminals of the NTAK28 Junction Box are connected to a clean DC power source meeting the requirements shown in the following table. [Major]

DC power requirements for each NTDK72 DC power supply

	Minimum	Nominal	Maximum
Input Range	-44 V DC	-52 V DC	-54 V DC
Noise (CMESS)	—	—	25 dBrc
Current	—	—	12 Amps
AC Ripple	—	—	100 mv RMS

Power & Grounding for Systems with DC Power

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310) National Electrical Code (NEC) Article 300

- 14. Battery cells are floated at the manufacturer's recommended voltage.

(13.5 to 13.8 for 12VDC cells; 11.25 to 11.5 for 10VDC cells) [Major]

- 15. Battery cells do not exhibit signs of corrosion. [Major]

- 16. Observations/Comments

Battery Installation Worksheet

Manufacturer: _____ Number of Cells per String: _____
TYPE: _____ TOTAL STRING VOLTAGE: _____

CELL VOLTAGES

String A	String B	String C	String D
1 _____	1 _____	1 _____	1 _____
2 _____	2 _____	2 _____	2 _____
3 _____	3 _____	3 _____	3 _____
4 _____	4 _____	4 _____	4 _____
Totals: _____	Totals: _____	Totals: _____	Totals: _____
Cell Float Voltage Requirement:		Minimum	Maximum
		54 VDC _____	_____

Cabinet Installation

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310)

1. The mounting surface can support at least 100 lb (45 kg).

2. In installations with wall-mounted systems (recommended), the cabinet is secured to a backboard consisting of 3/4-in. (20-mm) plywood, or other similar material.

3. The plywood backboard is securely anchored to the wall with a minimum of six of the following listed fasteners: (**Wood studs**-use #10 wood screws with a 1” embedment; **Metal studs**- use #14 sheet metal screws with a 1” embedment; **Concrete**- ¼” Ramset Dynabolt sleeve anchors)

[Recommended; Critical in earthquake zones 4 &5]

4. System cabinets are secured with (2) #14 screws mounted near the bottom of the cabinet grates. [Major]

5. SDI ports on Fiber Receiver circuit cards are to be used only as maintenance ports. (No CDR, PMS, Traffic, etc.) [Major]

6. In installations with vertical expansion, the Expansion Cabinet is mounted above the Main Cabinet. (Avaya does not recommend vertical expansion of three or more cabinets.)

7. There is at least 12 in. (305 mm) between the top of a cabinet and the ceiling to ensure proper ventilation.

8. There is at least 10 in. (255 mm) between the bottom of the lower cabinet and the floor to prevent water damage and to allow for convectional cooling.

9. The cross-connect terminal is not above a cabinet. [Recommendation]

10. Adequate space for the battery backup unit is allowed, accounting for the cable-length limitation as determined by the choice of a wall-mounted or floor-mounted battery back-up unit.

Cabinet Installation

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310)

- 11. In multi-cabinet systems incorporating remote cabinets, the maximum distance between the Main Cabinet and each Expansion Cabinet is 1.8 mi (3 km).
- 12. Circuit cards are of allowable vintage (no outstanding Product Advisories/Bulletins). [Major]
- 13. Circuit cards are locked into place. [Minor]
- 14. Interiors of cabinets are not used as storage for screws, disks, cable ties, etc. [Major]

Application Tapes & Messaging System Tape Cartridges

- 15. Media is not subject to rapid changes in temperature or humidity. [Major]
- 16. Media is kept away from strong magnetic fields. [Major]
- 17. Database backups are routinely performed and are readily available. [Major]
- 18. System installation CDs, PC cards are available for the PBX and Applications products in the event of severe system hardware malfunction or data corruption. [Critical]
- 19. Observations/Comments

Cabling Installation

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310)

Outside Plant Cabling and Protectors

- 1. Entrance cable sheath is grounded as close as possible at the point of entry to an approved ground source. [Major] (NEC 800-33; 40)
- 2. Splice cases are properly grounded. [Major]

Cabling Installation

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310)

- 3. Approved protection devices are used for Telco network and campus cables. (Carbon, Gas tube type for network cables; fast-acting, low let-through type on campus cables). (NEC 800) [Major]
- 4. Protection devices are installed at both ends of a cable in a campus environment. (Silicon Avalanche type. see Oneac 5SDP; 5SAP) [Major] ANSI/UL 497-1995 Specs -10V for digital sets; 48VDC for analog sets.
- 5. All protection device grounding conductors are grounded to an approved source with an appropriately sized wire. The grounding conductors must be kept as short and straight as possible. (No sharp bends- 8" radius) (NEC 800-40) [Major]

Cabinet Cabling

- 6. Power cables are installed in correct cabinet grooves, where applicable, and securely fastened. [Major]
- 7. Cabling must be installed in a neat and orderly fashion. [Major]
- 8. MDF cables are seated and secured in place using factory velcro straps. [Major]
- 9. All MDF/IDF blocks are clearly labeled. [Major]
- 10. All cables for cabinets, Call Servers, Media Gateways/Expanders, Signaling Servers (SDI, AUX, VGMC ELAN/TLAN, CE-MUX, DS-30X, and 10/100BaseT cables) and adapters are properly fastened. [Major]
- 11. Fiber optic cables are routed according to the Optic cable routing guide. [Major]
- 12. Fiber optic cables are not bent beyond a 35mm bend. (90 degree soft bend) [Major]
- 13. The excess fiber optic cable is wound loosely around the optical cable storage device. [Major]

Cabling Installation

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Installation and Commissioning (NN43011-310)

- | | | |
|-----|--|-------|
| 14. | In IP survivable CS 1000 Cabinet systems, excess CAT 5 cable length is wound around the storage device. [Major] | _____ |
| 15. | EMI mitigating ferrite rings (NTVQ83AA) are installed on Voice Gateway Media Card TLAN/ELAN patch cables. [Major] | _____ |
| 16. | NTCW84JA assemblies are used for each VGMC connector. [Major] | _____ |
| 17. | CAT 5 patch cables are not installed near fluorescent lighting fixtures. [Major] | _____ |
| 18. | ELAN/TLAN patch cables for VGMC and Signaling Server hardware are “factory made” and kept at 20 feet or less. [Recommendation] | _____ |
| 19. | All patch cables are labeled and correlate to a network infrastructure diagram/schematic. [Minor] | _____ |
| 20. | PBX cabling is not strapped to the exterior of any conduit or raceway as a means of support. [Major] | _____ |
| 21. | M2250 consoles utilize 5 consecutive units and are properly cross-wired with three power TNs. The “AUX” cable may be utilized to take the place of two power TNs only!! See console cable wh/sl, rd/or, & rd/grn pairs [Major] | _____ |
| 22. | Observations/Comments | _____ |

System Operation

Meets
Specifications
Y / N

X11 Software General Release Bulletin (shipped with new software)

1.1.1 System Diagnostics

1. LD 30 Network and Signaling Diagnostic (NWS). [Minor]

2. LD 34 Tone and Digit Switch and Digitone Receiver (TDS). [Major] Check results from the midnight routines.

3. LD 37 Input/Output Diagnostic (IOD). Use "STAT" command for TTYs [Major]

4. LD 38 Conference Circuit Diagnostic (CNF) [Major] Check results from the midnight routines.

5. LD 43 Data Dump (EDD). [Critical] Check for successful completion of a manual data dump.

6. LD 44 Software Audit (AUD). [Major] Must be configured in BKGD of Ld-17. Check for normal AUD000 messages.

7. LD 48 Status of ELAN/ Mail/ESDI Links. [Major] Make sure all AMLs that are in use are ACTIVE EMPTY.

8. LD 60 Digital Trunk Diagnostic (DTI/PRI). [Major] Use the SSCK command to check system clocks. Also check midnight routines for frame slips, CRC errors.

9. GTR, technical publications, and Backup logs are located in switch room. Note: Ensure appropriate level and system type of technical publications are available. [Minor]

System Operation

Meets
Specifications
Y / N

X11 Software General Release Bulletin (shipped with new software)

1 The PBX maintenance modem/terminal server performs as expected. [Major]

0

.

11. Recommended level PEPs are installed in the system. This includes DepList PEPs for the call servers, required PEPs for Signaling Servers, and Voice Gateway Media Card PEPs.

[Recommendation]

12. A PC is available on location in order to access Element Manager/NRS [Major]

13. IP sets are on the latest recommended firmware. [Recommendation]

14. Signaling Servers are load sharing (equal number of registered IP phones) [Recommendation]

15. Printouts of Signaling Server config.ini and bootp.tab files readily available. [Minor]

pdt> cd /u/config, copy config.ini, copy bootp.tab

Memory size

16. The installation meets the minimum memory requirements for CS 1000 Release 5.5 software.

CS 1000 Release 5.5 memory requirements			
Processor	Flash memory required	DRAM memory required	Total memory
SSC	64 MByte	32 MByte	96 MByte

System Operation

Meets
Specifications
Y / N

X11 Software General Release Bulletin (shipped with new software)

- The installation does not exceed the maximum call register count recommended for CS 1000 Release 5.5 software.

Recommended maximum call register counts			
	Recommended	Memory	Memory
	call register	required	required
System	count	(SL-1 words)	(MByte)
CS 1000	800	181 600	0.693
Note: Call registers are 227 SL-1 words long. One SL-1 word is 4 bytes.			

- Observations/Comments

System Software

Meets
Specifications
Y / N

For additional information refer to:

Software Input Output Reference System Messages (NN43001-712)

Overlay 15/21 Customer Data Block

- SRCD (Auto Set Relocation Code) has a value programmed (0000 is Okay). [Major if SPRE is 1, Minor if other]

Overlay 17/22 Configuration Record

- Daily Routine defined as LD 34, 38, 60,137 [Major]

System Software

Meets
Specifications
Y / N

For additional information refer to:

Software Input Output Reference System Messages (NN43001-712)

- 3. LD 44 in background routine. [Major]
- 4. The number of call registers (NCR) within the maximum value required per GRB documentation regarding port size and features used.
1000- 800 call registers [Major]
- 5. 1000 LPIB and HPIB values equal 450 [Recommendation]
- 6. History File is defined as MTC, BUG and is set at minimum length of 60,000 characters. [Major]
- 7. ERRM is configured as ERR, BUG, AUD [Major]
- 8. 1.1.2 RLS IDs are configured for each D-Channel where appropriate. [Major]

Overlay 11/12/13 Digital Sets / Attendant Consoles/ Digitone Receivers

- 9. Switchroom phone requires MTA for class of service. [Major]
- 10. Consoles powered via unused TNs are correctly programmed “PWR”. [Major]
- 11. Consoles are cross-wired properly and must utilize consecutive units. [Major]
- 12. Observations/Comments

Networking Parameters for VoIP

Meets
Specifications
Y / N

For additional information refer to:

Meridian 1 Small System Planning and Engineering (NN43011-220)

Meridian 1 Small System Installation and Commissioning (NN43011-310)

1. A LAN/WAN assessment has been performed on the customer network. [Critical] _____

2. The layer 2 switch ports (Baystack 470) in place for the CS 1000 ELAN/TLAN are configured for full duplex, auto negotiate. [Major] _____

3. The port speed for ELAN related ports are configured at 10 Mbps for CS 1000 systems. [Major] _____

4. The ELAN subnet and the TLAN subnet are on separate subnets. [Major] _____

5. All applications on the ELAN subnet are on the same subnet. [Major] _____

6. The port speed for all TLAN ports on the layer 2 switch are configured for 100 Mbps [Major] _____

7. VGMC circuit cards in the same node are on the same TLAN subnet. [Major] _____

8. Minimum of one VGMC DSP resource for every TDM port (T-1 trunks, digital phones, analog phones, analog trunks, Avaya CallPilot channels). [Recommendation] _____

For non-blocking requirements one DSP per TDM port is a best practice.

9. Layer 2/3 switches derive UPS power from different branch circuit sources, if possible, in order to minimize single points of failure. [Recommendation] _____

10. Signaling Server (ISP 1100, CP PM, COTS) _____

11. Observations/Comments _____

