

POWER REQUIREMENTS FOR COMMUNITY
CENTRAL OFFICE EQUIPMENT

Contents

1. GENERAL
2. BASIS FOR CALCULATIONS
3. CALCULATIONS

- FIGURE 1 - AG COMMUNICATIONS, GTD No. 5 EAX
FIGURE 2 - ALCATEL, 1210/32, 1210/64
FIGURE 3 - ALCATEL, E10-FIVE
FIGURE 4 - NORTHERN TELECOM, (4-1) DMS-100, (4-2) -10-400
FIGURE 5 - STROMBERG-CARLSON DCO
FIGURE 6 - NEC AMERICA NEAX (6-1) 61ES, (6-2), 61EM
FIGURE 7 - REDCOM MDX
FIGURE 8 - TRANSMISSION ELECTRONICS CURRENT DRAIN
FIGURE 9 - ESTIMATING TELEPHONE BATTERY SIZES
FIGURE 10 - CHARGER CAPACITY

1. GENERAL

1.1 This section is intended to provide REA borrowers, consulting engineers, contractors and other interested parties with technical information for use in the design and construction of REA borrowers' telephone systems. It discusses, in particular, the methods used in calculating the power requirements for central offices. It provides means to calculate the required capacities of the storage batteries and charging equipment for particular applications.

1.2 This revision replaces REA TE&CM 302, Issue No. 5, dated January 1987. It is being reissued to include some new power calculation methods for various digital, stored program controlled central office equipment.

1.3 Paragraphs 12.1 and 12.2, respectively, of Part III, REA Form 522, "Specification for Digital, Stored Program Controlled Central Office Equipment," cover the general specifications governing the supply, by the manufacturer, of storage battery and charging equipment for use with an REA borrower's proposed central office equipment (COE). Based upon these general specifications, determination of the required capacities of the battery and charger is made by the manufacturer.

2. BASIS FOR CALCULATIONS

2.1 The charging equipment furnished with a central office must have sufficient capacity to supply the dc power necessary for the satisfactory operation of the office during the busy hour. This includes the dc requirements for carrier, loop extenders, voice frequency repeaters, and dc-dc converters or dc-ac inverters to operate input/output devices.

2.1.1 Determination of the requirements for emergency generating and charging equipment is covered in REA TE&CM 320, "Emergency Generating and Charging Equipment." The computation of charger size to meet the site charging requirement is described in figure 10 - Charger Capacity.

2.2 Charging equipment for digital central offices should be provided on one of the following bases:

(a) Two chargers either capable of carrying the full office load, or

(b) Three chargers each capable of carrying half the office load, or

Arrangement (a) may be used in any central office power system.

Arrangement (b) may be used and offers potential cost savings when applied to power requirements in relatively large digital, stored program controlled offices.

2.3 Storage Battery

2.3.1 The storage battery furnished with a central office must have sufficient capacity to supply the dc power necessary to sustain satisfactory operation of the exchange for the period specified. See paragraph 1.3 for location of specific requirements in the central office equipment specifications. This includes appropriate allowances for any equipment which is normally ac operated but arranged for dc operation in case of a power failure.

2.3.2 During battery discharge, the minimum usable voltage to be delivered to the central office equipment is determined by the COE manufacturer's design criteria. When power flows from the battery through the power board to the equipment, a voltage drop (IR loss) is experienced as a result of the resistance of the current carrying conductors. In many cases the equipment design is based on 44 volts being available at the power entry to the bay. Performance of the COE at voltages less than 44 volts becomes unpredictable. The electromechanical systems used earlier were capable of operation at voltages below 40 volts.

The voltage drop to the equipment bay is controlled by allocation as follows:

Battery to Power Board	0.5
Power Board to Equipment Bay	0.5
Minimum Equipment Voltage	<u>44.0</u>
Total	45V dc

In the case of a 24-cell battery $(45/24) = 1.88$ volts per cell becomes the minimum operating voltage.

2.3.3 The computation of battery size to meet the site power requirement is described in Figure 9 - Estimating Telephone Battery Sizes. This method permits computation with differing numbers of hours of reserve and number of cells in the battery string. The computation is applicable to lead acid batteries - either lead antimony or lead calcium (see manufacturer's data for capacity, dimensions, etc.).

2.3.4 Battery capacities are generally given in terms of ampere hour (AH) rating, when discharged to 1.75 volts per cell, in an 8-hour period. Since many REA financed systems are equipped with emergency generators, the period of discharge of their batteries is reduced to 3 hours. When a battery is discharged at a rate faster than 8 hours, the ampere hour rating is effectively reduced, e.g., at 3 hours approximately 75 percent of the 8-hour rating is available. The net effect of the 3-hour discharge is to require a battery of approximately half the size required to carry the same load for 8 hours ($3 \times \text{load in amps} / 0.75 = 4$ hours equivalent vs. 8-hour rating).

2.3.5 The selection of the battery capacity to be supplied is based on the power outages experienced at the site and the evaluation of the future performance of the ac power system. Another consideration is the size of the dc load to be supplied. Small electromechanical switching systems have a limited amount of fixed power consuming devices, while a large part of the system only requires power when in use. This gave rise to considering the power required in the "busy hour." Industry usage considered 8 busy hour battery capacity appropriate for most small installations. The expectation of 8 consecutive busy hours of usage following a power interruption was nil, resulting in battery power being usable for longer than the 8-hour period. Power consumption in digital switching equipment is almost constant, whether or not calls are being processed. In addition, the total power consumed by the digital switch is greater than the electromechanical systems. The concept of "busy hour drain" has lost its impact in digital offices where the operating drain represents the constant load. The solution most often used is to provide an emergency generator to supply power on a long-term basis and to install a battery with 3 hours' capacity.

3. CALCULATIONS

3.1 The following sample calculations describe the procedure to determine the power requirements for digital, stored program controlled central office equipment. Sample calculations are included for the following switching equipment types:

<u>Manufacturer</u>	<u>System Designation</u>
Figure 1 - AG	GTD No. 5 EAX
Figure 2 - Alcatel	1210/32, 64
Figure 3 - Alcatel	E10-FIVE
Figure 4 - Northern Telecom	DMS-100, DMS-10
Figure 5 - Stromberg-Carlson	DCO
Figure 6 - NEC America	NEAX 61 ES, 61EM
Figure 7 - Redcom	MDX

3.2 Figure 8: Lists various power requirements for loop extenders, voice frequency repeaters, carrier equipment and other equipment.

3.3 Figure 9: Illustrates the method used in determining the capacity of the storage battery required for a particular application. This exhibit also illustrates, in Example 2, a method used to calculate the ampere hour reserve of existing batteries when the current requirement of the central office equipment is changed as a result of equipment additions, higher than anticipated calling rates, etc.

3.4 Figure 10: Illustrates the method used in determining charger capacity required for a particular application. In connection with the calculation of the required capacity of the charger, a 10 percent allowance is made, i.e., if 110 percent of the rated output of the charger is equal to or greater than the calculated charger dc current requirement, the charger supplied shall be considered as satisfactorily meeting the specification requirements. Three solutions in terms of the number of chargers and their capacity are included.

3.5 In some cases specialized equipment requires power at a voltage different from the -48V dc central office battery. Dc-dc converters can be supplied at $\pm 24V$ dc, $\pm 48V$ dc, $\pm 130V$ dc and other values. These other voltages are used to supply radio and carrier equipment operated at -24 volts, coin collect circuits at ± 130 volts and other equipment. The power required by the dc-dc converters must be included in the total load to be carried by the central office dc power system.

3.6 It should be kept in mind that the calculation methods shown in this section are to provide estimates only. Engineering judgment must be used for each individual application. It is, therefore, recommended that the manufacturer of the system be consulted for specific applications.

Figure 1 AG COMMUNICATION SYSTEMS GTD-5 EAX

DC POWER

1. Peripheral Equipment

Line Power Consumption:

5.56 to 7.20 CCS/line	Lines	_____	x 1.02	=	_____	Watts
4.00 to 5.55 CCS/line	Lines	_____	x 0.90	=	_____	Watts
0.00 to 3.99 CCS/line	Lines	_____	x 0.78	=	_____	Watts

Analog Trunk Unit Power Consumption:

5.56 to 7.20 CCS/line	Lines	_____	x 0.00568	=	_____	
4.00 to 5.55 CCS/line	Lines	_____	x 0.004256	=	_____	
0.00 to 3.99 CCS/line	Lines	_____	x 0.00332	=	_____	
Number of Analog Trunks						
Incoming MF CCS	_____	x 0.00073	=	_____		
Analog Trunk Unit Constant				=	92.00	
Analog Trunk Unit Total				=	_____	
(Analog Trunk Unit Total/192)*		x 805.23		=	_____	Watts

Digital Trunk Power Consumption:

Office T1 Spans	_____	x 15.07	=	_____	Watts
-----------------	-------	---------	---	-------	-------

2. Network Equipment

Time Switch Power Consumption:

5.56 to 7.20 CCS/line	Lines	_____ / 750	=	_____	
4.00 to 5.55 CCS/line	Lines	_____ / 1128	=	_____	
0.00 to 3.99 CCS/line	Lines	_____ / 1520	=	_____	
Analog Trunk Unit Total		_____ / 192	=	_____	
Office T1 Spans		_____ / 8	=	_____	
Total Time Switch Facility Interface Units		_____			
(Time Switch FIU's _____/4)*		x 669.19	=	_____	Watts

Space Switch Power Consumption:

(Time Switch FIU's _____/4)*		x 371.30 + 277	=	_____	Watts
------------------------------	--	----------------	---	-------	-------

* All computations in parentheses must be rounded up to the nearest integer before proceeding.

Figure 1 AG GTD-5 EAX (Page 2)

3. Common Control Equipment

Processor Power Consumption:
 (Busy Hour Attempts _____ / 45,000)* x 393.38 = _____ Watts

Office Memory Power Consumption:
Office Busy Hour Attempts:
 Up to 45,000 BHA, Enter "0"
 Up to 135,000 BHA, Enter "1"
 Up to 180,000 BHA, Enter "2"
 Up to 315,000 BHA, Enter "3"
 148.75 + (Value Selected _____ x 29.17)* = _____ Watts

Message Distributor Power Consumption:
 (Office Busy Hour Attempts _____ / 45,000)* = _____
 (Time Switch FIU's _____ / 4)* = _____
 Distributor Constant 1.00
 Distributor Total Processors _____
 (Distributor Total Processors _____ / 2)* x 35 + 57.44 = _____ Watts

Magnetic Tape Power Consumption:
 Magnetic Tape Drives _____ x 173.52 = _____ Watts

- | | |
|---|----------------------|
| 4. GTD-5 Constant Power | <u>1371.79</u> Watts |
| 5. Miscellaneous Power | <u>1000.00</u> Watts |
| 6. Office Total Power | _____ Watts |
| 7. Heat Dissipation | _____ Watts |
| 8. DC Drain in Amperes | |
| Office Total Power _____ / 50 = _____ Amperes | |

NOTES:

- 1) Use only for GTD-5 EAX's having fewer than 18,000 lines.
- 2) The office BHCA (e.g. 45,000) reflects a class 5 configuration without centrex capabilities.

* All computations in parentheses must be rounded up to the nearest integer before proceeding.

Figure 1 GTE COMMUNICATION SYSTEMS GTD-5 EAX

E X A M P L E #1

1,000 Lines @ 3.2 CCS/line, 50 Analog Trunks & 3 T1 Spans at 20 CCS/Trk.

DC POWER

1. Peripheral Equipment

Line Power Consumption:

5.56 to 7.20 CCS/line	Lines	_____	x 1.02	=	_____	Watts
4.00 to 5.55 CCS/line	Lines	_____	x 0.90	=	_____	Watts
0.00 to 3.99 CCS/line	Lines	<u>1,000</u>	x 0.78	=	<u>780.00</u>	Watts

Analog Trunk Unit Power Consumption:

5.56 to 7.20 CCS/line	Lines	_____	x 0.00568	=	_____
4.00 to 5.55 CCS/line	Lines	_____	x 0.004256	=	_____
0.00 to 3.99 CCS/line	Lines	<u>1,000</u>	x 0.00332	=	<u>3.32</u>
Number of Analog Trunks					<u>50.00</u>
Incoming MF CCS	<u>921</u>	x 0.00073		=	<u>0.67</u>
Analog Trunk Unit Constant					<u>92.00</u>
Analog Trunk Unit Total					<u>145.99</u>
(Analog Trunk Unit Total/192)* x 805.23				=	<u>805.23</u> Watts

Digital Trunk Power Consumption:

Office T1 Spans	<u>3</u>	x 15.07	=	<u>45.21</u> Watts
-----------------	----------	---------	---	--------------------

2. Network Equipment

Time Switch Power Consumption:

5.56 to 7.20 CCS/line	Lines	_____ / 750	=	_____
4.00 to 5.55 CCS/line	Lines	_____ / 1128	=	_____
0.00 to 3.99 CCS/line	Lines	<u>1,000</u> / 1520	=	<u>0.66</u>
Analog Trunk Unit Total		<u>145.99</u> / 192	=	<u>0.76</u>
Office T1 Spans	<u>3</u>	/ 8	=	<u>0.38</u>
Total Time Switch Facility Interface Units		<u>1.80</u>		
(Time Switch FIU's <u>1.8</u> / 4)* x 669.19				= <u>669.19</u> Watts

Space Switch Power Consumption:

(Time Switch FIU's <u>1.80</u> / 4)* x 371.30 + 277	=	<u>648.30</u> Watts
---	---	---------------------

* All computations in parentheses must be rounded up to the nearest integer before proceeding.

Figure 1 GTE GTD-5 EAX (Page 2)

E X A M P L E #1

3. Common Control Equipment

Processor Power Consumption:
(Busy Hour Attempts 1,947/45,000) x 393.38 = 393.38 Watts

Office Memory Power Consumption:
Office Busy Hour Attempts:
Up to 45,000 BHA, Enter "0"
Up to 135,000 BHA, Enter "1"
Up to 180,000 BHA, Enter "2"
Up to 315,000 BHA, Enter "3"
148.75 + (Value Selected 0 x 29.17)* = 148.75 Watts

Message Distributor Power Consumption:
(Office Busy Hour Attempts 1,947/45,000)* = 1.00
(Time Switch FIU's 1.80/4)* = 1.00
Distributor Constant 1.00
Distributor Total Processors 3.00
(Distributor Total Processors 3/2)* x 35 + 57.44 = 127.44 Watts

Magnetic Tape Power Consumption:
Magnetic Tape Drives 2 x 173.52 = 347.04 Watts

- 4. GTD-5 Constant Power 1371.79 Watts
- 5. Miscellaneous Power 1000.00 Watts
- 6. Office Total Power 6336.33 Watts
- 7. Heat Dissipation 6336.63 Watts
- 8. DC Drain in Amperes
Office Total Power 6336.33/50 = 126.73 Amperes

NOTES:

- 1) Use only for GTD-5 EAX's having fewer than 18,000 lines.
- 2) The office BHCA (e.g. 45,000) reflects a class 5 configuration without centrex capabilities.

* All computations in parentheses must be rounded up to the nearest integer before proceeding.

Figure 1 GTE COMMUNICATION SYSTEMS GTD-5 EAX

E X A M P L E #2

2,152 Lines @ 3.2 CCS/line, 5 Analog Trunks & 11 T1 Spans at 20 CCS/Trk.

DC POWER

1. Peripheral Equipment

Line Power Consumption:

5.56 to 7.20 CCS/line	Lines	_____	x 1.02	=	_____	Watts
4.00 to 5.55 CCS/line	Lines	_____	x 0.90	=	_____	Watts
0.00 to 3.99 CCS/line	Lines	<u>2152</u>	x 0.78	=	<u>1678.56</u>	Watts

Analog Trunk Unit Power Consumption:

5.56 to 7.20 CCS/line	Lines	_____	x 0.00568	=	_____		
4.00 to 5.55 CCS/line	Lines	_____	x 0.004256	=	_____		
0.00 to 3.99 CCS/line	Lines	<u>2152</u>	x 0.00332	=	<u>7.14</u>		
Number of Analog Trunks						<u>5.00</u>	
Incoming MF CCS <u>2421</u> x 0.00073						<u>1.77</u>	
Analog Trunk Unit Constant						<u>92.00</u>	
Analog Trunk Unit Total						<u>105.91</u>	
(Analog Trunk Unit Total/192)* x 805.23						<u>= 805.23</u>	Watts

Digital Trunk Power Consumption:

Office T1 Spans	<u>11</u>	x 15.07			<u>= 165.77</u>	Watts
-----------------	-----------	---------	--	--	-----------------	-------

2. Network Equipment

Time Switch Power Consumption:

5.56 to 7.20 CCS/line	Lines	_____	/ 750	=	_____		
4.00 to 5.55 CCS/line	Lines	_____	/1128	=	_____		
0.00 to 3.99 CCS/line	Lines	<u>2152</u>	/1520	=	<u>1.42</u>		
Analog Trunk Unit Total						<u>105.91/ 192 = 0.55</u>	
Office T1 Spans						<u>11/ 8 = 1.38</u>	
Total Time Switch Facility Interface Units						<u>3.33</u>	
(Time Switch FIU's <u>3.33/4</u>)* x 669.19						<u>= 669.19</u>	Watts

Space Switch Power Consumption:

(Time Switch FIU's <u>3.33/4</u>)* x 371.30 + 277					<u>= 648.30</u>	Watts
--	--	--	--	--	-----------------	-------

* All computations in parentheses must be rounded up to the nearest integer before proceeding.

Figure 1 GTE GTD-5 EAX (Page 2)

E X A M P L E #2

3. Common Control Equipment

Processor Power Consumption:

$$\text{(Busy Hour Attempts } \underline{4,494/45,000})^* \times 393.38 = \underline{393.38} \text{ Watts}$$

Office Memory Power Consumption:

Office Busy Hour Attempts:

Up to 45,000 BHA, Enter "0"

Up to 135,000 BHA, Enter "1"

Up to 180,000 BHA, Enter "2"

Up to 315,000 BHA, Enter "3"

$$148.75 + (\text{Value Selected } \underline{0} \times 29.17)^* = \underline{148.75} \text{ Watts}$$

Message Distributor Power Consumption:

$$\text{(Office Busy Hour Attempts } \underline{4,494/45,000})^* = \underline{1.00}$$

$$\text{(Time Switch FIU's } \underline{3.33 / 4})^* = \underline{1.00}$$

$$\text{Distributor Constant} = \underline{1.00}$$

$$\text{Distributor Total Processors} = \underline{3.00}$$

$$\text{(Distributor Total Processors } \underline{3 / 2})^* \times 35 + 57.44 = \underline{127.44} \text{ Watts}$$

Magnetic Tape Power Consumption:

$$\text{Magnetic Tape Drives } \underline{2} \times 173.52 = \underline{374.04} \text{ Watts}$$

4. GTD-5 Constant Power 1371.79 Watts

5. Miscellaneous Power 1000.00 Watts

6. Office Total Power 7355.45 Watts

7. Heat Dissipation 7355.45 Watts

8. DC Drain in Amperes

$$\text{Office Total Power } \underline{7355.45/50} = \underline{147.11} \text{ Amperes}$$

Use only for GTD-5 EAX's having fewer than 18,000 lines.

* All computations in parentheses must be rounded up to the nearest integer before proceeding.

Figure 2 ALCATEL 1210/32, 1210/64

DC DRAIN

1210 Host:

_____ Lines at 3 CCS x .032 = _____ Amps
_____ Lines at 4 CCS x .035 = _____ Amps
_____ Lines at 5 CCS x .038 = _____ Amps
Add 60 Amps = 60 Amps
Add Customer DC Requirements = _____ Amps
Total DC Drain = _____ Amps

1210 Remote Line Switch:

_____ Lines at 3 CCS x .026 = _____ Amps
_____ Lines at 4 CCS x .030 = _____ Amps
_____ Lines at 5 CCS x .034 = _____ Amps
Add 7 Amps = 7 Amps
Add Customer DC Requirements = _____ Amps
Total DC Drain = _____ Amps

1210 Remote Switching Unit:

_____ Lines at 3 CCS x .033 = _____ Amps
_____ Lines at 4 CCS x .036 = _____ Amps
_____ Lines at 5 CCS x .039 = _____ Amps
Add 22 Amps = 22 Amps
Add Customer DC Requirements = _____ Amps
Total DC Drain = _____ Amps

HEAT DISSIPATION

Total DC Drain x 51.8 Volts = _____ Watts

Figure 2 ALCATEL 1210/32, 1210/64

E X A M P L E

DC DRAIN

1210 Host: 1,000 Lines

<u>1000</u> Lines at 3 CCS x .032	=	<u>32</u>	Amps
_____ Lines at 4 CCS x .035	=	_____	Amps
_____ Lines at 5 CCS x .038	=	_____	Amps
Add 60 Amps	=	<u>60</u>	Amps
Add Customer DC Requirements	=	_____	Amps
Total DC Drain	=	<u>92</u>	Amps

1210 Remote Line Switch: 2,100 Lines

<u>2100</u> Lines at 3 CCS x .026	=	<u>55</u>	Amps
_____ Lines at 4 CCS x .030	=	_____	Amps
_____ Lines at 5 CCS x .034	=	_____	Amps
Add 7 Amps	=	<u>7</u>	Amps
Add Customer DC Requirements	=	_____	Amps
Total DC Drain	=	<u>62</u>	Amps

1210 Remote Switching Unit: 6,000 Lines

<u>6000</u> Lines at 3 CCS x .033	=	<u>198</u>	Amps
_____ Lines at 4 CCS x .036	=	_____	Amps
_____ Lines at 5 CCS x .039	=	_____	Amps
Add 22 Amps	=	<u>22</u>	Amps
Add Customer DC Requirements	=	_____	Amps
Total DC Drain	=	<u>220</u>	Amps

HEAT DISSIPATION (Example is for 1000 line host office)

Total DC Drain x 51.8 Volts = 92 x 51.8 = 4766 Watts

Figure 3 ALCATEL E10-FIVE

DC DRAIN

<u>EQUIPMENT</u>	<u>QUANTITY</u>	<u>MULTIPLY BY</u>	<u>AMPS</u>
Total Lines (Idle Drain)	_____	.005	_____
Total Lines (Occupied Drain)	_____	.0012 x CCS	_____
Control TCU Cabinet	_____	12.94	_____
Matrix Cabinet (Up to 5000L)	_____	7.67	_____
Common Equipment (Up to 4000L)	_____	10.0	_____
Line Cabinet	_____	.44	_____
AMA	_____	8.36	_____
Miscellaneous OEM	_____		_____
T1 (24 Channel)	_____	1.08	_____
(48 Channel)	_____	1.85	_____
(72 Channel)	_____	2.62	_____
(96 Channel)	_____	3.40	_____
		TOTAL AMPS	_____
		CUSTOMER DRAIN	_____

HEAT DISSIPATION

Heat Dissipation (WATTS) = 51.2 x DC Drain = _____ Watts

BTU/Hour = 3.41 x Watts

Figure 3 ALCATEL E10-FIVE

E X A M P L E
2,000 Lines @ 3.2 CCS/Line

DC DRAIN

<u>EQUIPMENT</u>	<u>QUANTITY</u>	<u>MULTIPLY BY</u>	<u>AMPS</u>
Total Lines (Idle Drain)	<u>2000</u>	.005	<u>10.0</u>
Total Lines (Occupied Drain)	<u>2000</u>	.0012 x CCS	<u>7.68</u>
Control TCU Cabinet	<u>1</u>	12.94	<u>12.94</u>
Matrix Cabinet (Up to 5000L)	<u>1</u>	7.67	<u>7.67</u>
Common Equipment (Up to 4000L)	<u>1</u>	10.0	<u>10.0</u>
Line Cabinet	<u>3</u>	.44	<u>1.32</u>
AMA	<u> </u>	8.36	<u> </u>
Miscellaneous OEM	<u>1 ea</u>		<u>10.0</u>
T1 (24 Channel)	<u> </u>	1.08	<u> </u>
(48 Channel)	<u> </u>	1.85	<u> </u>
(72 Channel)	<u> </u>	2.62	<u> </u>
(96 Channel)	<u>2</u>	3.40	<u>6.8</u>
		TOTAL AMPS	<u>66.41</u>
		CUSTOMER DRAIN	<u> </u>

HEAT DISSIPATION

Heat Dissipation (WATTS) 51.2 x DC Drain = 3400.2 Watts

BTU/Hour = 3.41 x Watts
BTU/Hour = 3.41 x 3400.2
BTU/Hour = 11,595

Figure 4-1 NORTHERN TELECOM DMS-100

DC DRAIN

1. Basic (CPU)	<u>78.5</u>
CC Frame E/W 4 Memory Shelves	
I/O Frame E/W 2 Disk + 1 Mag Tape	
2. PDC Bays _____ x 6.5 Amps	_____
3. LAMA or CAMA (10 Amps)	_____
4. Combined Network Frame _____ x 24 Amps	_____
5. Double Shelf Network _____ x 14 Amps	_____
6. DTC _____ x 9.2 Amps	_____
7. MTM _____ x 3.3 Amps	_____
8. TM _____ x 2.2 Amps	_____
9. LGC _____ x 9.3 Amps	_____
10. Line Circuits	
$9x \left(\frac{\text{Avg. 2-Way ABSBH CCS/Line}}{8} \right) x \text{ No. of LCM} \quad _ +$	
$+1 + \left(5x \left(\frac{\text{Avg. 2-W ABSBH CCS/Line}}{8} \right) x \text{ No. of LCE} \quad _ +$	
$+3.6 + \left(\frac{4.2 x \text{ (Avg. 2-W ABSBH CCS/Line)}}{8} \right) x \text{ No. of LCM} \quad _ =$	_____
	Subtotal _____
Customer Drain _____	_____
DMS Current Total _____	_____

CC - Central Controller
PDC - Power Distribution Center
DTC - Digital Trunk Controller
LGC - Line Group Controller
MTM - Maintenance Trunk Module
TM - Trunk Module

Figure 4-1 NORTHERN TELECOM DMS-100

HEAT DISSIPATION

<u>Type of Frame</u>	<u>Quantity</u>	<u>Heat Dissipation Per Frame (Watts/Hr)</u>	<u>Total Heat Dissipation</u>
Central Control Complex	_____	1720	_____
Input/Output Frame	_____	850	_____
Miscellaneous Equipment	_____	220	_____
Network Combined	_____	1000	_____
Digital Trunk Equipment	_____	1120	_____
Trunk Module Equipment Frame	_____	480	_____
Line Concentrating Equipment	_____	1050	_____
Line Group Equipment	_____	980	_____
Power Distribution Center	_____	200	_____
		TOTAL WATTS/HOUR	_____

Figure 4-1 NORTHERN TELECOM DMS-100

E X A M P L E

1400 Lines, 50 Digital Trunks, 50 Analog Trunks, 3.2665/L

HEAT DISSIPATION

<u>Type of Frame</u>	<u>Quantity</u>	<u>Heat Dissipation Per Frame (Watts/Hr)</u>	<u>Total Heat Dissipation</u>
Central Control Complex	<u>1</u>	1720	<u>1720</u>
Input/Output Frame e/w	<u>1</u>	850	<u>850</u>
Miscellaneous Equipment	<u>1</u>	220	<u>220</u>
Network Combined	<u>1</u>	1000	<u>1000</u>
Digital Trunk Equipment	<u>1</u>	1120	<u>1120</u>
Trunk Module Equipment Frame	<u>2</u>	480	<u>960</u>
Line Concentrating Equipment	<u>1</u>	1050	<u>1050</u>
Line Group Equipment	<u>1</u>	980	<u>980</u>
Power Distribution Center	<u>1</u>	200	<u>200</u>
		TOTAL WATTS/HOUR	<u>8100</u>

Figure 4-2 DMS-10 D.C. CURRENT DRAIN

Figure 4-2 NORTHERN TELECOM STANDARD DMS-10 400 SERIES

DC DRAIN

Basic System

DCM Shelves	_____	x	<u>4</u>	=	_____	Amps
DCI Shelf	_____	x	<u>3</u>	=	_____	Amps
SCM-10S	_____	x	<u>10</u>	=	_____	Amps
P.E. Shelf	_____	x	<u>0.75</u>	=	_____	Amps
LCE Lines	_____	x	<u>0.015</u>	=	_____	Amps
BMC	_____	x	<u>5</u>	=	_____	Amps
D.C./A.C. Inverter (0.5 KW)					_____	Amps
				Total =	_____	Amps

Heat Dissipation

D.C. Drain

Northern Telecom DMS-10 400 Generic (3 Bay)

Basic System

P.E. Shelf	_____	x	<u>0.75</u>	=	_____	Amps
DCM Shelf	_____	x	<u>4</u>	=	_____	Amps
LCE Lines	_____	x	<u>0.015</u>	=	_____	Amps
				Total	_____	Amps

Heat Dissipation

D.C. Drain	_____	x	<u>52</u>	=	_____	Watts
------------	-------	---	-----------	---	-------	-------

DMS-10 D.C. CURRENT DRAIN

Figure 4-2 NORTHERN TELECOM STANDARD DMS-10 400 SERIES

Example #1

Northern Telecom Standard DMS-10 400 Series

5000 Lines, 576 Trunks, 1 RLCM, 1 SLC-96, 1 RSLE, 1 RSLM
@ 3.2 CCS/line

DC Drain

Basic System				<u>25</u>	Amps
DCM Shelves	<u>4</u>	x	<u>4</u>	=	<u>16</u> Amps
DCI Shelf	<u>1</u>	x	<u>3</u>	=	<u>3</u> Amps
SCM-10S	<u>1</u>	x	<u>10</u>	=	<u>10</u> Amps
P.E. Shelf	<u>2</u>	x	<u>0.75</u>	=	<u>1.5</u> Amps
LCE Lines	<u>5000</u>	x	<u>0.015</u>	=	<u>75</u> Amps
BMC	<u>2</u>	x	<u>5</u>	=	<u>10</u> Amps
D.C./A.C. Inverter (0.5 KW)					<u>15</u> Amps
			Total =		<u>155.5</u> Amps

Heat Dissipation

DC Drain	<u>155.5</u>	x	<u>52</u>	=	<u>8086</u> Watts
----------	--------------	---	-----------	---	-------------------

Example #2

Northern Telecom DMS-10 400 Generic (3 Bay)

1280 Lines, 144 Trunks, @ 3.2 CCS

Basic System					<u>30</u> Amps
P.E. Shelf	<u>2</u>	x	<u>0.75</u>	=	<u>1.5</u> Amps
DCM Shelf	<u>1</u>	x	<u>4</u>	=	<u>4</u> Amps
LCE Lines	<u>1280</u>	x	<u>0.015</u>	=	<u>19.2</u> Amps
			Total =		<u>54.7</u> Amps

Heat Dissipation

D.C. Drain	<u>54.7</u>	x	<u>52</u>	=	<u>2844</u> Watts
------------	-------------	---	-----------	---	-------------------

DMS-10 D.C. CURRENT DRAIN

Figure 4-2 NORTHERN TELECOM STANDARD DMS-10 400 SERIES

<u>1 - Standard 400 Series</u>	<u>AMPS</u>
Basic System Current Drain	25.0
Network Module (Max. = 2 Modules)	12.0
DCM Shelf	4.0
DCI Shelf	3.0
SCM-10 (DMS-1) Shelf	4.0
SCM-10S (SLC-96) Module	10.0
Mag Tape Bay	7.8
BMC (each)	5.0
DC/AC Inverter 0.5 KW	15.0
DC/AC Inverter 1.0 KW	26.0
P.E. Lines	0.020
P.E. Shelf (with service circuits)	0.75
LCM Lines (per line)	0.015
 <u>2 - DMS-10 400 Series (3 bay)</u>	 <u>AMPS</u>
Basic System Current Drain (includes combination CPU/Network shelf and GPIO shelf)	30.0
 <u>3 - DMS-10 400 series (2 bay)</u>	 <u>AMPS</u>
CONTROL AND TRUNK BAY	
CPU/Network Shelf (5.8 amps ea. <u>two required</u>)	11.6
GPIO Shelf	4.8
T & M Shelf	2.9
PCCM Shelf	1.5
DAT Shelf	2.9
LINE AND TRUNK BAY	
Two Shelf LCM (E/W 640 Lines)	9.6
Bay Supervisory Panel	0.2
DAT Shelf each (max. = 2 shelves)	2.9
 <u>4 - DMS-10 400 Series (1 bay)</u>	 <u>AMPS</u>
CPU/Network Shelf (5.8 amps ea. <u>two required</u>)	11.6
T & M Shelf	2.9
PCCM Shelf	1.5
DAT Shelf	2.9
FSP (Frame Supervisory Panel) and LCM Shelf (E/W 256 lines)	4.8

DMS-10 D.C. CURRENT DRAIN (Page 2)

Figure 4.2 NORTHERN TELECOM STANDARD DMS-10 400 SERIES

<u>5 - OPM</u>	<u>AMPS</u>
One Cabinet Line Current	15 0.015/L
<u>6 - OPSM</u>	<u>AMPS</u>
One Cabinet Line Current	9 0.015/L
<u>7 - RSLM</u>	<u>AMPS</u>
RSLM Bay Line Current	6 0.015/L
<u>8 - RSLE</u>	<u>AMPS</u>
RSLE Bay (up to 512 lines)	10.5
RSLE Bay (from 512 to 1024 lines)	21
Line Current	0.015/L
<u>9 - RLCM</u>	<u>AMPS</u>
RLCM Bay	10
LCE Bay	0.015/L

DAT - Digital Analog Trunk
DCM - Digital Carrier Module
DCI - Digital Carrier Interface
GPIO - General Purpose Input Output
LCE - Line Concentrating Equipment (uses 6X___ type circuits)
OPM - Outside Plant Module
OPSM - Outside Plant Subscriber Module
PCCM - Power Cooling Control Module
P.E. - Peripheral Equipment (uses 2T___ type circuits)
RLCM - Remote Line Concentrator Module
RSLM - Remote Subscriber Line Module
RLSE - Remote Line Subscriber Equipment
SCM - Subscriber Carrier Module
T&M - Trunk and Maintenance

FIGURE 5 STROMBERG-CARLSON DCO

DC DRAIN

1. DCO Frame Power Calculations

Local Line Switch Power:

Quantity of Lines = _____	x	CCS/L	x	0.696	=	_____
Quantity of Lines	=	_____	x	0.1583	=	_____
Quantity of Line CUAs	=	_____	x	27.91	=	_____
Quantity of RLG Host CUAs	=	_____	x	145.4	=	_____
Quantity of SLC-96 (Mode 1) CUAs	=	_____	x	130.5	=	_____
Quantity of SLC-96 (Mode 2) CUAs	=	_____	x	123.3	=	_____
Quantity of LLS Frames	=	_____	x	2.52	=	_____

TOTAL LLS POWER REQUIREMENTS _____ WATTS

Line/Trunk Frame Power:

Quantity of DTMF Receiver PWBA's	=	_____	x	9.39	=	_____
Quantity of TMF Receiver PWBA's	=	_____	x	6.90	=	_____
Quantity of TMF Sender PWBA's	=	_____	x	2.39	=	_____
Quantity of Busy Verif. PWBA's	=	_____	x	14.46	=	_____
Quantity of Analog Trunk PWBA's	=	_____	x	8.2	=	_____
Quantity of LTF CUAs	=	_____	x	18.53	=	_____

TOTAL LTF POWER REQUIREMENTS _____ WATTS

Digital Trunk Frame Power:

Quantity of T1 Interface PWBA's	=	_____	x	16.0	=	_____
Quantity of Message Assem. PWBA's	=	_____	x	46.88	=	_____
Quantity of DTF CUAs	=	_____	x	73.36	=	_____

TOTAL DTF POWER REQUIREMENTS _____ WATTS

CMF/CCEF Power:

Quantity of TSI PWBA's	=	_____	x	123.0	=	_____
Quantity of MP's	=	_____	x	229.57	=	_____
Quantity of Memory PWBA's	=	_____	x	15.61	=	_____
Quantity of RNSs (7 Max)	=	_____	x	56.82	=	_____
Quantity of Sectors (4 Max)	=	_____	x	492.9	=	_____
CMF Common Drain	=	_____			=	<u>724.19</u>

TOTAL CMF/CCEF POWER REQUIREMENTS _____ WATTS

Figure 5 STROMBERG-CARLSON DCO (Page 2)

Power, Ringing & Test Frame Power:
 Preferential Ringing Frequencies = _____ x 52 = _____
 First PRT Frame = _____ = 104
 Second PRT (> 2 Sectors) = _____ x 92 = _____
 TOTAL PRT POWER REQUIREMENTS _____ WATTS

AMA/CODC Power:
 AMA Frame = _____ x 392 = _____
 CODC Data Collector Frame = _____ x 586 = _____
 TOTAL AMA/CODC POWER REQUIREMENTS _____ WATTS

Common Equipment Frame Power:

Item/Model No.	Quantity	Power
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
TOTAL CEF POWER REQUIREMENTS	_____	WATTS

Miscellaneous Equipment Power:

Item/Model No.	Quantity	Power
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
TOTAL MISCELLANEOUS EQUIPMENT POWER REQUIREMENTS	_____	WATTS

Figure 5 STROMBERG-CARLSON DCO (Page 3)

2. DCO System DC Power Summary

Total Local Line Switch Power	_____	WATTS
Total Digital Trunking Power	_____	WATTS
Total Line/Trunk Frame Power	_____	WATTS
Total CMF/CCEF Power	_____	WATTS
Total Power, Ringing and Test Power	_____	WATTS
Total AMA/CODC Power	_____	WATTS
Total Common Equipment Frame Power	_____	WATTS
Total Miscellaneous Equipment Power	_____	WATTS
Total Customer's Equipment Power	_____	WATTS
 TOTAL DCO SYSTEM DC POWER REQUIREMENTS	 _____	 WATTS
TOTAL DC BUSY HOUR LOAD (_____ WATTS/52.1 Volts)	_____	AMPS

3. RLS Frame Power Calculations

Remote Line Switch Power:

Quantity of Lines = _____	x	_____	CCS/L	x	.0696	=	_____
Quantity of Lines		=	_____	x	0.1583	=	_____
Quantity of Line CUAs		=	_____	x	27.91	=	_____
Quantity of RLG Host CUAs		=	_____	x	145.4	=	_____
Quantity of SLC-96 (Mode 1) CUAs		=	_____	x	130.5	=	_____
Quantity of SLC-96 (Mode 2) CUAs		=	_____	x	123.3	=	_____
Quantity of ESS Feature		=	_____	x	75.0	=	_____
Quantity of PGHs		=	_____	x	13.6	=	_____
Quantity of RLS I Frames		=	_____	x	683.24	=	_____
Quantity of RPRF		=	_____	x	166.0	=	_____

TOTAL RLS POWER REQUIREMENTS	_____	WATTS
TOTAL DC BUSY HOUR LOAD (_____ WATTS/52.1 Volts)	_____	AMPS

Figure 5 STROMBERG-CARLSON DCO

E X A M P L E
1,000 Lines, 3.2 CCS

DC DRAIN

1. DCO Frame Power Calculations

Local Line Switch Power:

Quantity of Lines = 1000	x	3.2 CCS/L	x	.069	=	221
Quantity of Lines	=	1000	x	0.1583	=	158
Quantity of Line CUAs	=	12	x	27.91	=	335
Quantity of RLG Host CUAs	=	0	x	145.4	=	0
Quantity of SLC-96 (Mode 1) CUAs	=	0	x	130.5	=	0
Quantity of SLC-96 (Mode 2) CUAs	=	0	x	123.3	=	0
Quantity of LLS Frames	=	1	x	2.52	=	2.52

TOTAL LLS POWER REQUIREMENTS 717 WATTS

Line/Trunk Frame Power:

Quantity of DTMF Receiver PWBA's	=	3	x	9.39	=	28
Quantity of TMF Receiver PWBA's	=	2	x	6.90	=	14
Quantity of TMF Sender PWBA's	=	3	x	2.39	=	7
Quantity of Busy Verif. PWBA's	=	2	x	14.46	=	29
Quantity of Analog Trunk PWBA's	=	3	x	8.2	=	25
Quantity of LTF CUAs	=	2	x	18.53	=	37

TOTAL LTF POWER REQUIREMENTS 140 WATTS

Digital Trunk Frame Power:

Quantity of T1 Interface PWBA's	=	5	x	16.0	=	80
Quantity of Message Assem. PWBA's	=	0	x	46.88	=	0
Quantity of DTF CUAs	=	1	x	73.36	=	73

TOTAL DTF POWER REQUIREMENTS 153 WATTS

CMF/CCEF Power:

Quantity of TSI PWBA's	=	2	x	123.0	=	246
Quantity of MP's	=	1	x	229.57	=	230
Quantity of Memory PWBA's	=	2	x	15.61	=	31
Quantity of RNSs (7 Max)	=	0	x	56.82	=	0
Quantity of Sectors (4 Max)	=	1	x	492.9	=	493
CMF Common Drain	=				=	724.19

TOTAL CMF/CCEF POWER REQUIREMENTS 1724 WATTS

Figure 5 STROMBERG-CARLSON DCO (Page 2)

E X A M P L E

Power, Ringing & Test Frame Power:

Preferential Ringing Frequencies	=	<u>4</u>	x	52	=	<u>208</u>
First PRT Frame					=	<u>104</u>
Second PRT (> 2 Sectors)	=	<u> </u>	x	92	=	<u> </u>

TOTAL PRT POWER REQUIREMENTS 312 WATTS

AMA/CODC Power:

AMA Frame	=	<u> </u>	x	392	=	<u> </u>
CODC Data Collector Frame	=	<u> </u>	x	586	=	<u> </u>

TOTAL AMA/CODC POWER REQUIREMENTS WATTS

Common Equipment Frame Power:

Item/Model No.	Quantity	Power
<u>Digital Recorded Announcer</u>	<u> </u>	<u>64</u>
<u>Test Generator</u>	<u> </u>	<u>55</u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>

TOTAL CEF POWER REQUIREMENTS 119 WATTS

Miscellaneous Equipment Power:

Item/Model No.	Quantity	Power
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>

TOTAL MISCELLANEOUS EQUIPMENT POWER REQUIREMENTS 0 WATTS

Figure 5 STROMBERG-CARLSON DCO (Page 3)

E X A M P L E

2. DCO System DC Power Summary

Total Local Line Switch Power	717	WATTS
Total Digital Trunking Power	153	WATTS
Total Line/Trunk Frame Power	140	WATTS
Total CMF/CCEF Power	1724	WATTS
Total Power, Ringing and Test Power	304	WATTS
Total AMA/CODC Power	0	WATTS
Total Common Equipment Frame Power	119	WATTS
Total Miscellaneous Equipment Power	0	WATTS
Total Customer's Equipment Power	0	WATTS
TOTAL DCO SYSTEM DC POWER REQUIREMENTS	3157	WATTS
TOTAL DC BUSY HOUR LOAD (<u>3165</u> WATTS/52.1 Volts)	60.7	AMPS

3. RLS Frame Power Calculations

Remote Line Switch Power:

Quantity of Lines = <u>1000</u> x <u>3.2</u> CCS/L x .069	=	<u>221</u>
Quantity of Lines	=	<u>1000</u> x 0.1583 = <u>158</u>
Quantity of Line CUAs	=	<u>12</u> x 27.91 = <u>335</u>
Quantity of RLG Host CUAs	=	<u>0</u> x 145.4 = <u>0</u>
Quantity of SLC-96 (Mode 1) CUAs	=	<u>0</u> x 130.5 = <u>0</u>
Quantity of SLC-96 (Mode 2) CUAs	=	<u>0</u> x 123.3 = <u>0</u>
Quantity of ESS Feature	=	<u>1</u> x 75.0 = <u>75</u>
Quantity of PGHs	=	<u>4</u> x 13.6 = <u>54</u>
Quantity of RLS I Frames	=	<u>1</u> x 683.24 = <u>683</u>
Quantity of RPRF	=	<u>1</u> x 166.0 = <u>166</u>
TOTAL RLS POWER REQUIREMENTS	1692	WATTS
TOTAL DC BUSY HOUR LOAD (<u>1692</u> WATTS/52.1 Volts)	32.5	AMPS

Figure 6-1 NEC America NEAX 61ES

DC DRAIN

	<u>Quantity</u>	<u>Multiply By</u>	<u>Amps</u>
Idle Switch Drain			<u>30.50</u>
Time Switch Frames(1)	<u> </u>	<u>14</u>	<u> </u>
Digital Transmission Interface(2)	<u> </u>	<u>1.3</u>	<u> </u>
Line & Trunk Frames	<u> </u>	<u>9</u>	<u> </u>
Analog Trunks	<u> </u>	<u>0.02</u>	<u> </u>
Total Busy Hour Traffic (CCS)	<u> </u>	<u>0.001</u>	<u> </u>
Customer Drain			<u> </u>
TOTAL DC DRAIN			<u> </u>

NOTES:

- (1) 1 per 2880 ports.
- (2) 1 per five T1 span lines.

HEAT DISSIPATION

Heat Dissipation (Watts) = 52.7 x DC Drain = Watts

Figure 6-1 NEC America NEAX 61ES

E X A M P L E
1,000 Lines, 50 Digital Trunks, 50 Analog Trunks, 3.2 CCS/L

DC DRAIN

	<u>Quantity</u>	<u>Multiply By</u>	<u>Amps</u>
Idle Switch Drain			<u>30.50</u>
Time Switch Frames(1)	<u>1</u>	<u>14</u>	<u>14</u>
Digital Transmission Interface(2)	<u>1</u>	<u>1.3</u>	<u>1.3</u>
Line & Trunk Frames	<u>2</u>	<u>9</u>	<u>18</u>
Analog Trunks	<u>50</u>	<u>0.02</u>	<u>1</u>
Total Busy Hour Traffic (CCS)	<u>3200</u>	<u>0.001</u>	<u>3.2</u>
Customer Drain			<u>20</u>
TOTAL DC DRAIN			<u>88</u>

NOTES:

- (1) 1 per 2880 ports.
- (2) 1 per five T1 span lines.

HEAT DISSIPATION

Heat Dissipation (Watts) = 52.7 x DC Drain 88 = 4637.6 Watts

Figure 6-2. NEC America NEAX 61EM

DC DRAIN

	<u>Quantity</u>	<u>Multiply By</u>	<u>Amps</u>
Idle Switch Drain			<u>37.50</u>
Time Switch Frames(1)	<u> </u>	<u>14</u>	<u> </u>
Digital Transmission Interface(2)	<u> </u>	<u>1.3</u>	<u> </u>
Line & Trunk Frames	<u> </u>	<u>9</u>	<u> </u>
Analog Trunks	<u> </u>	<u>0.02</u>	<u> </u>
Total Busy Hour Traffic (CCS)	<u> </u>	<u>0.001</u>	<u> </u>
Customer Drain			<u> </u>
TOTAL DC DRAIN			<u> </u>

NOTES:

- (1) 1 per 2880 ports.
- (2) 1 per five T1 span lines.

HEAT DISSIPATION

Heat Dissipation (Watts) = 52.7 x DC Drain = Watts

Figure 6-2 NEC America NEAX 61EM

E X A M P L E
1,000 Lines, 50 Digital Trunks, 50 Analog Trunks, 3.2 CCS/L

DC DRAIN

	<u>Quantity</u>	<u>Multiply By</u>	<u>Amps</u>
Idle Switch Drain			37.50
Time Switch Frames(1)	1	14	14
Digital Transmission Interface(2)	1	1.3	1.3
Line & Trunk Frames	2	9	18
Analog Trunks	50	0.02	1
Total Busy Hour Traffic (CCS)	3200	0.001	3.2
Customer Drain			20
TOTAL DC DRAIN			95

NOTES:

- (1) 1 per 2880 ports.
- (2) 1 per five T1 span lines.

HEAT DISSIPATION

Heat Dissipation (Watts) = 52.7 x DC Drain 95 = 5006.50 Watts

FIGURE 7 REDCOM MDX

DC DRAIN

	<u>Quantity</u>	<u>Multiply By</u>	<u>Amps</u>
MSU Shelves (One per 40 Lines)	_____	3.5	_____

HEAT DISSIPATION

Heat Dissipation (Watts) = 52.1 x DC Drain _____ = _____ Watts

E X A M P L E
150 Lines

DC DRAIN

	<u>Quantity</u>	<u>Multiply By</u>	<u>Amps</u>
MSU Shelves (One per 40 Lines)	4	3.5	14

HEAT DISSIPATION

Heat Dissipation (Watts) = 52.1 x DC Drain 14 = 730 Watts

Figure 8 TRANSMISSION ELECTRONICS CURRENT DRAIN

<u>Equipment</u>	<u>48-Volt Battery Drain Amperes Per Unit</u>
Loop Extenders	0.075
<u>VF Repeaters</u>	
1. Negative Impedance	0.035
2. Hybrid	0.035
3. Automatic Gain Control	0.080
4. Loop Extender/Repeater Combination	0.100
5. Automatic Gain Control Loop Extender/Repeater Combination	0.200
<u>Carrier Systems</u>	
1. D1 or D2	3.0
2. D3 (24 Channel)	0.7
3. D4 (24 Channel)	0.35
4. T1 Span Line	0.6
5. N1 or N2	1.8
6. N3 (24 Channel)	3.0
7. Station Carrier (1 Channel)	0.04
8. Station Carrier (Multi-Channel) Per Channel	0.1
9. Pair Gain Devices (Switching) (See Notes 1 & 2 for Office End)	
<u>Echo Cancellor</u>	
1. VF (1 Channel)	0.075
2. Digital (24 Channel)	1.7
<u>Remote Office Line Test</u>	
1. Test Console (110V ac, 0.4A)	0.7
2. Remote Terminal	0.7
<u>Maintenance and Control Center</u>	
<u>120V, 60Hz Load Amperes Per Unit (Note 3)</u>	
<u>Colocated with COE:</u>	
Video Display (CRT)	0.5
Printer (1200 Baud)	0.5
<u>Remotely Located:</u>	
Teletypewriter (e/w 300 Baud Modem)	0.35

NOTES:

1. Refer to the manufacturer's data sheets for specific current drain requirements.
2. Line concentrators or other pair gain devices incorporating switching functions are generally locally powered at remote site.
3. Voltage: 95 to 128V ac - Frequency: 48 to 65HZ

Figure 9 ESTIMATING TELEPHONE BATTERY SIZES

Number of Hours Reserve	8-Hour Ampere Hour Capacity Required for Each Ampere of Load					
	Final Cell Voltages					
	1.75	1.80	1.85	1.88	1.90	1.95
1	2.2	2.5	2.8	3.2	3.5	5.0
2	3.2	3.4	3.7	4.3	4.7	6.2
3	4.0	4.3	4.7	5.2	5.6	7.5
4	4.9	5.1	5.6	6.1	6.5	8.6
5	5.7	6.0	6.5	7.0	7.4	9.6
6	6.5	6.8	7.3	7.8	8.2	10.6
7	7.2	7.6	8.1	8.7	9.1	11.6
8	8.0	8.3	8.9	9.6	10.0	12.6
9	8.8	9.1	9.6	10.4	10.9	13.7
10	9.5	9.9	10.4	11.4	12.0	15.0
Voltage (24 Cells)	42	43.2	44.4	45.1	45.6	46.8

EXAMPLES:

1. Required: The capacity of a 24-cell battery to handle a 3-hour load of 34.0 amperes to a limited voltage of 45 volts.

$$45/24 = 1.88$$

From the above chart, each ampere of load requires 5.2 ampere hours of capacity.

Total capacity required = 5.2 x 34.0 = 177 ampere hours. Select next larger catalog size.

2. Calculate the ampere hour reserve of an existing 24-cell, 480-ampere hour battery with the load increased to 69 amperes to a final voltage of 1.88 volts.

Formula: $K = B/C$

Where

K = 8-hour ampere hour capacity required for each ampere of load.

B = Ampere hour capacity of existing battery.

C = Actual current drain of all equipment.

$$K = 480/69 = 7.0$$

On the chart, locate 7.0 in the 1.88-volt column and to the left read 5 hours' reserve.

Figure 10 CHARGER CAPACITY

The battery charger must supply power for operation of the COE. Its capacity should be great enough to carry the entire load, including peak power requirements, to avoid taking power from the battery. Additional capacity is required to recharge the battery after a power service interruption.

EXAMPLE:

Drain	66 Amps
Battery Discharged for 3 Hours and Recharged in 12 Hours: $3 \times 66 / 12 =$	16.5 Amps
Calculated Charger DC Current Requirement	82.5 Amps
Rated Charger Capacity (as indicated in item 3.4)	75 Amps

The charger capacity sizes commercially available include:

- 2 @ 75 Amps - Traditional arrangement with load sharing between the two chargers.
- 3 @ 50 Amps - Potential cost saving over buying two larger units. Potential operating cost saving by operating only two units.

APPENDIX APOWER REQUIREMENTS FOR DIRECT CONTROL AND
COMMON CONTROL ELECTROMECHANICAL SWITCHING SYSTEMS

1. GENERAL

1.1 The power requirements described in this appendix are for the older electromechanical switching systems that are still in use. These computations may be used in estimating power requirements associated with additions or rearrangements of the existing switching systems.

2. CALCULATIONS

2.1 Attached Exhibits A through N outline the procedures to be followed in calculating the power requirements (charger and battery) for dial central office equipment of the following types:

EXHIBIT A - Switch Type Equipment as Manufactured by
Automatic Electric, ITT and Stromberg-Carlson

North Electric NX-2A Crossbar Equipment

Leich All-Relay Equipment

EXHIBIT B - Stromberg-Carlson ESC-1

EXHIBIT C - Stromberg-Carlson ESC-3

EXHIBIT D - ITT A-1

EXHIBIT E - ITT PC-32B

EXHIBIT F - Automatic Electric CXP-5

EXHIBIT G - Automatic Electric No. 1 EAX

EXHIBIT H - North Electric NX-1D

EXHIBIT I - North Electric NX-1E

EXHIBIT J - Northern Electric SP-1

EXHIBIT K - Nippon Electric NC-23, NC-400, and NC-460

EXHIBIT L - Stromberg-Carlson Toll Ticketing

EXHIBIT M - ITT Tel Touch

EXHIBIT N - Stromberg-Carlson Tone Dialing

EXHIBIT A

Busy Hour Current Drain Calculations
for Various Switchboards
(All Values in Amperes)

Type of Drain	Switch Type (XY, SxS)	North NX-2A Crossbar	Leich Dial (Linefinder-Selector-Connector)
Equipment Holding (See Note 1)	0.72/T.C.U.	0.6/T.C.U. (See Note 5)	1.17/T.C.U.
General Operating	0-100 Lines 1.0 101-200 Lines 1.5 201-400 Lines 2.0 401+ Lines 3.0	1st Line Group 1.0 Each Add'l. Line Group 0.5	4.0
Additional Equipment	-	-	0.3/100 Lines
Manual Toll Board	2.0/Position	2.0/Position	2.0/Position
DC Operated Ringing Generator (See Note 2)	0-100 Lines 2.0 101+ Lines 3.0	3.0	0-100 Lines 2.0 101+ Lines 3.0
Interoffice Trunk Circuit	0.35/2W & 1W Incoming Trunk 0.30/1W Outgoing Trunk (See Note 4)	0.25/Trunk (See Note 4)	1.08/T.T.C.U. (See Note 6)
Special Equipment (See Note 3)	As Required	As Required	As Required

EXHIBIT A NOTES

Notes:

1. A "Time Call" Unit is calculated as follows:

$$\text{T.C.U.} = \frac{\text{Unit Calls Per Line} \times \text{Total Number of Lines}}{36}$$

2. When the primary ringing generator is ac operated, no provision need be made in the charger capacity to handle the standby ringing generator. The generator drain must be included when calculating battery capacity.
3. This includes the power requirements for carrier, loop extenders, voice frequency repeaters, ANI, etc. Where special equipment is normally ac operated and requires dc only for standby, no provision need be made in the charger capacity. The drain must be included when calculating battery capacity.
4. If the number of interoffice trunk groups equals four or more for switch type equipment (more than four for NX-2A), it is satisfactory to use three-quarters ($\frac{3}{4}$) of the total trunk circuit current drain.
5. When conversation time disconnect is equipped, add 0.2 amperes per T.C.U. to the holding drain.
6. A Trunk "Time Call" Unit (T.T.C.U.) is calculated as follows:
- $$\text{T.T.C.U.} = \frac{\text{Unit Call Capacity of Trunk Group (P.01)}}{36}$$
7. If the total busy hour drain is not in excess of ten percent above a standard charger size, that charger may be used. If the above total exceeds ten percent, the next larger standard charger size should be used.

Examples:

The following office will be used in each of these examples. Assume a 360 line office has a calling rate of 2.0 unit calls per line with 6 two-way toll trunks and 8 two-way EAS trunks terminated on incoming selectors. Also assume that dc operated carrier and VF repeaters have a drain of 3 amperes. The primary ringing generator is ac operated in Examples 1 and 3.

$$\text{T.C.U.} = \frac{2.0 \text{ UC/L} \times 360 \text{ Lines}}{36} = 20$$

Exhibit A Examples Continued

1. Switch Type Equipment:

Equipment Holding Drain = 20 X 0.72	= 14.4
General Operating Drain	= 2.0
No Toll Board	-
Primary Ringing Generator - AC Operated	-
Trunk Drain = 14 X 0.35	= 4.9
Special Equipment Drain	= 3.0
Total Drain	<u>24.3</u> Amps

2. North NX-2A Crossbar:

Equipment Holding Drain = 20 X 0.6	= 12.0
General Operating Drain = 1.0 + $\frac{270}{90}$ X 0.5	= 2.5
Primary Ringing Generator - DC Operated	= 3.0
Trunk Drain = 14 X 0.25	= 3.5
Special Equipment Drain	= 3.0
Total Drain	<u>24.0</u> Amps

3. Leich Dial:

Equipment Holding Drain = 20 X 1.17	= 23.4
General Operating Drain	= 4.0
Additional Equipment Drain = $\frac{360}{100}$ X 0.3	= 1.1
Primary Ringing Generator - AC Operated	-
Trunk Drain:	
6 Toll Trunks (P.01) will handle 64.4 UC	
Toll Group Drain = $\frac{64.4}{36}$ X 1.08	= 1.9
8 EAS Trunks (P.01) will handle 105 UC	
EAS Group Drain = $\frac{105}{36}$ X 1.08	= 3.2
Special Equipment Drain	= 3.0
Total Drain	<u>36.6</u> Amps

The above total drains should be used in determining charger size. For calculating battery capacity three amperes should be added to Examples 1 and 3 to account for ringing generator current drain.

EXHIBIT B

Stromberg-Carlson ESC-1

Equipment	48-Volt Drain			8-Volt Drain		
	No. of Units	Amperes Per Unit	Total Current	No. of Units	Amperes Per Unit	Total Current
Common Control (Local) Cabinets (CCL) 1	-	-	-	-	16	-
4-Stage Trunk Link Network(TLN)	-	93	-	-	-	-
6-Stage Trunk Link Network(TLN)	-	102	-	-	-	-
Common Control(Trunk) Cabinets (CCT)	-	10	-	-	7	-
Register Sender Cabinets(RS)	-	1	-	-	10	-
Auxiliary Register Sender Cabinets (RSA)	-	3	-	-	10	-
Translator Cabinets	-	5	5	-	42	42
TLN Cabinet(Control) (TLC)	1	10	10	1	8	8
Supervisory Cabinet (CSR)	1	6	6	1	12	12
Powerboard (1 Frequency)	-	7	-	-	-	-
(2 Frequencies)	-	9	-	-	-	-
(4 Frequencies)	-	15	-	-	-	-
Automatic Call Generator	1	3	3	1	5	5
DC-DC Converter (-24v) 2	-	11	-	-	-	-
Loop Extender Power Supply 2	-	4	-	-	-	-
Pre-Pay Power Supply	-	2	-	-	-	-
Tandem Trunks 3	-	.015	-	-	-	-
Recording Trunks	-	Note 4	-	-	Note 4	-
LAMA Cabinets	-	24	-	-	16	-
CAMA Cabinets	-	13	-	-	7	-
Maintenance Test Console	-	5	-	-	2	-
Registers	-	-	-	-	1	-
Senders	-	-	-	-	1	-
Customer Drain	-	As Req'd.	-	-	As Req'd.	-
Total Drain	48-Volt			8-Volt		

EXHIBIT B NOTES

Notes:

1. When the number of line units are odd, round off to next even number.
2. Do not include drain for redundant equipment.
3. Incoming Tandem Trunk CCS X .015 = Total Current

4.

<u>Recording Trunks Equipped</u>	<u>Drain in Amperes</u>	
	<u>48-Volt</u>	<u>8-Volt</u>
1 - 50	7	57
51 - 100	8	68
101 - 150	9	79
151 - 200	10	90
201 - 250	11	102
251 - 300	13	113
301 - 350	14	124
351 - 400	15	136

5. When SCAMA-LAMA ticketing is required, the following drains should be added:

<u>Ultimate DDD Trunk Capacity</u>	<u>8V Drain</u>	<u>48V Drain</u>
50	57 amps	7 amps
100	68	8
150	79	9
200	90	10
250	111	11
300	113	13
350	124	14
400	136	15

6. When CAMA is required, the following drains should be added:

48V Drain - 24 amps
8V Drain - 16 amps

EXAMPLE

Stromberg-Carlson ESC-1
1500 Lines
5000 Directory Numbers

Equipment	48-Volt Drain			8-Volt Drain		
	No. of Units	Amperes Per Unit	Total Current	No. of Units	Amperes Per Unit	Total Current
Common Control (Local) Cabinets (CCL) 1	-	-	-	1	16	16
4-Stage Trunk Link Network (TLN)	1	93	93	-	-	-
6-Stage Trunk Link Network (TLN)		102		-	-	-
Common Control (Trunk) Cabinets (CCT)	1	10	10	1	7	7
Register Sender Cabinets (RS)	1	1	1	1	10	10
Auxiliary Register Sender Cabinets (RSA)		3			10	
Translator Cabinets	-	5	5	-	42	42
TLN Cabinet (Control) (TLC)	1	10	10	1	8	8
Supervisory Cabinet (CSR)	1	6	6	1	12	12
Powerboard (1 Frequency)		7		-	-	-
(2 Frequencies)		9		-	-	-
(4 Frequencies)	1	15	15	-	-	-
Automatic Call Generator	1	3	3	1	5	5
DC-DC Converter (-24v) 2	1	11	11	-	-	-
Loop Extender Power Supply 2	2	4	8	-	-	-
Pre-Pay Power Supply	2	2	4	-	-	-
Tandem Trunks 3	100 CCS	.015	1.5	-	-	-
Recording Trunks		Note 4			Note 4	
LAMA Cabinets		24			16	
CAMA Cabinets	1	13	13	1	7	7
Maintenance Test Console	1	5	5	1	2	2
Registers	-	-	-	80	1	80
Senders	-	-	-	20	1	20
Customer Drain		As Req'd.	15		As Req'd.	
Total Drain		48-Volt	200.5		8-Volt	209

EXHIBIT C

Stromberg-Carlson ESC-3

Equipment	48-Volt Drain			8-Volt Drain		
	No. of Units	Amperes Per Unit	Total Current	No. of Units	Amperes Per Unit	Total Current
Common Control Cabinet		23.8			48.6	
Translator		4.2			77.7	
Test Cabinet		3.7			10.0	
Power Supervisory Register Common	-	24.7	-	-	-	-
Call Generator		-			12.0	
MF Current Supply		0.6			4.8	
Each Register (Max. 48)		2.8		-	-	-
Each Sender (Max. 20)	-	0.2	-	-	1.3	-
Each Tone Dial Detector		-			1.0	
Each 1,000 Directory Numbers	-	0.43	-	-	-	-
Each Toll MF Detector		-			5.6	
+48v Message Registration		0.5			-	
+48v Paystation Coin Control		3.5			-	
Aux. Common Control Cabinet		1.5			-	
Aux. Line/Trunk Marker		6.8			16.6	
Each Line Unit (1350 CCS)		4.2		-	14.0	-
Each Line Unit (2000 CCS)		20.3		-	-	-
Loop Extender Power Supply (3 amps per 49 loops)		30.0		-	-	-
Customer Drain		3.0			-	
		As Req'd.			As Req'd.	
Total Drain		48-Volt			8-Volt	

EXAMPLE

Stromberg-Carlson ESC-3
500 Lines
1000 Directory Numbers

Equipment	48-Volt Drain			8-Volt Drain		
	No. of Units	Amperes Per Unit	Total Current	No. of Units	Amperes Per Unit	Total Current
Common Control Cabinet	1	23.8	23.8	1	48.6	48.6
Translator	1	4.2	4.2	1	77.7	77.7
Test Cabinet	1	3.7	3.7	1	10.0	10.0
Power Supervisory	1	24.7	24.7	-	-	-
Register Common	-	-	-	1	12.0	12.0
Call Generator	1	0.6	.6	1	4.8	4.8
MF Current Supply	1	2.8	2.8	-	-	-
Each Register (Max. 48)	8	0.2	1.6	8	1.3	10.4
Each Sender (Max. 20)	-	-	-	5	1.0	5.0
Each Tone Dial Detector	-	0.43	-	-	-	-
Each 1,000 Directory Numbers	-	-	-	1	5.6	5.6
Each Toll MF Detector	-	0.5	-	-	-	-
+48v Message Registration	-	3.5	-	-	-	-
+48v Paystation Coin Control	-	1.5	-	-	-	-
Aux. Common Control Cabinet	-	6.8	-	-	16.6	-
Aux. Line/Trunk Marker	-	4.2	-	-	14.0	-
Each Line Unit (1350 CCS)	1	20.3	20.3	-	-	-
Each Line Unit (2000 CCS)	-	30.0	-	-	-	-
Loop Extender Power Supply (3 amps per 49 loops)	1	3.0	3.0	-	-	-
Customer Drain	-	As Req'd.	10.0	-	As Req'd.	-
Total Drain	48-Volt		94.7	8-Volt		174.1

EXHIBIT D

ITT A-1 Pentaconta

I. Speech Path Drain

CCS (Intraoffice)		x 0.007 =	
CCS (Outgoing)		x 0.007 =	
CCS (Incoming)		x 0.008 =	
Total			= Speech Path Drain

II. Register-Sender Drain

	EHC	RHT	EHCx RHT	
Intraoffice Calls				x 0.0008
Outgoing Calls				
Assistance				
CAMA				
TSPS				
EAS				
Other				
Total Outgoing				x 0.0014 =
Incoming Calls				
DDD				
EAS				
Other				
Total Incoming				x 0.0008 =
Total				= R-S Drain

EHC = Number of Busy Hour Calls
RHT = Register-Sender Holding Time

Exhibit D - Continued

III. Marker Drain

BHC (Intraoffice)		x 0.0085 =	
BHC (Outgoing)		x 0.0026 =	
BHC (Incoming)		x 0.0057 =	
		Total	

= Marker Drain

IV. Connector Drain

Total Marker Drain		x 0.2 =	
--------------------	--	---------	--

= Connector Drain

V. Customer Equipment Drain

As Required

Total Current Drain equals sum of I through V.

EXHIBIT E

ITT PC-32B

I. Speech Path Drain

CCS (Intraoffice)		x 0.022 =	
CCS (Outgoing)		x 0.017 =	
CCS (Incoming)		x 0.017 =	
Total			

= Speech Path Drain

II. Register-Sender Drain

	BHC	RET	BHC x RET	
Intraoffice Calls				x 0.00014 =
Outgoing Calls				
Assistance				
CAMA				
TSPS				
EAS				
Other				
Total Outgoing				x 0.00021 =
Incoming Calls				
DDD				
EAS				
Other				
Total Incoming				x 0.00056 =
Total				

= R-S
Drain

BHC = Number of Busy Hour Calls
RET = Register-Sender Holding Time

Exhibit E continued

III. Marker Drain

EHC (Intraoffice)			
EHC (Outgoing)			
EHC (Incoming)			
Total EHC		$\times 0.0019 =$	= Marker Drain

IV. Customer Equipment Drain

As Required

Total Current Drain Equals Sum of I through IV.

ITT A-1 Pentaconta
& PC-32B

Example

The following information is used to demonstrate the method used to calculate the current drain of the ITT A-1 and PC-32B systems.

2000 Lines		
1.6 CCS/Line Originating		
Outgoing Trunk Traffic		
Assistance	200 CCS	67 EHC
CAMA	400 CCS	167 EHC
EAS	800 CCS	533 EHC
Incoming Trunk Traffic		
DDD	600 CCS	250 EHC
EAS	800 CCS	533 EHC
Intraoffice Traffic	1800 CCS	1500 EHC
Register Holding Times		
Assistance	5 Seconds	
CAMA	17 Seconds	
Outgoing EAS	14 Seconds	
DDD	7 Seconds	
Incoming EAS	7 Seconds	
Intraoffice	14 Seconds	
Customer Equipment Drain	40 Amps	

EXAMPLE

ITT A-1 Pentaconta

I. Speech Path Drain

CCS (Intraoffice)	1800	x 0.007 =	12.6	
CCS (Outgoing)	1400	x 0.007 =	9.8	
CCS (Incoming)	1400	x 0.008 =	11.2	
		Total	33.6	= Speech Path Drain

II. Register-Sender Drain

	EHC	RET	EHCx RET		
Intraoffice Calls	1500	14	21,000	x 0.0008	16.8
Outgoing Calls					
Assistance	67	5	335		
CAMA	167	17	2839		
TSPS					
EAS	533	14	7462		
Other					
Total Outgoing	767		10,636	x 0.0014 =	14.9
Incoming Calls					
DDD	250	7	1750		
EAS	533	7	3731		
Other					
Total Incoming	783		5481	x 0.0008 =	4.4
			Total		36.1

- R-S Drain

EHC = Number of Busy Hour Calls
RET = Register-Sender Holding Time

EXAMPLE - Continued

III. Marker Drain

EHC (Intraoffice)	1500	x 0.0085 =	12.8	
EHC (Outgoing)	767	x 0.0026 =	2.0	
EHC (Incoming)	783	x 0.0057 =	4.5	
		Total	19.3	= Marker Drain

IV. Connector Drain

Total Marker Drain	19.3	x 0.2 =	3.9	= Connector Drain
--------------------	------	---------	-----	-------------------

V. Customer Equipment Drain

As Required

40 AMPS

Total Current Drain equals sum of I through V.

$$33.6 + 36.1 + 19.3 + 3.9 + 40.0 = 132.9 \text{ AMPS}$$

From the above ampere drain it is seen that either two 150 amp chargers or three 75 amp chargers should be provided. For a three-hour reserve, a 660 ampere-hour battery is required. (From Exhibit P, a final cell voltage of 1.85 yields a factor of 4.7 for a three-hour reserve. Therefore, 4.7 X 132.9 = 625 AH. The next larger size is 660 AH.)

EXAMPLE

ITT PC-32B

I. Speech Path Drain

CCS (Intraoffice)	1800	x 0.022 =	39.6	
CCS (Outgoing)	1400	x 0.017 =	23.8	
CCS (Incoming)	1400	x 0.017 =	23.8	
	Total		87.2	= Speech Path Drain

II. Register-Sender Drain

	BHC	RHT	BHC x RHT		
Intraoffice Calls	1500	14	21,000	x 0.00014 =	2.9
Outgoing Calls					
Assistance	67	5	335		
CAMA	167	17	2839		
TSPS					
EAS	533	14	7462		
Other					
Total Outgoing	767		10,636	x 0.00021 =	2.2
Incoming Calls					
DDD	250	7	1750		
EAS	533	7	3731		
Other					
Total Incoming	783		5481	x 0.00056 =	3.1
			Total		8.2 = R-S Drain

BHC = Number of Busy Hour Calls
RHT = Register-Sender Holding Time

EXAMPLE continued

III. Marker Drain

BHC (Intraoffice)	1500		
BHC (Outgoing)	767		
BHC (Incoming)	783		
Total BHC	3050	x 0.0019 =	5.8 = Marker Drain

IV. Customer Equipment Drain

As Required

40 AMPS

Total Current Drain Equals Sum of I through IV.

$$87.2 + 8.2 + 5.8 + 40.0 = 141.2 \text{ AMPS}$$

EXHIBIT F

Automatic Electric CXP-5

Subscriber Lines x CCS/Line =

_____ x _____ = _____

Delay Dial Trunks CCS = _____

Local Register-Sender CCS = _____

Non-Delay Dial Trunk Register-Sender CCS = _____

Total CCS = _____

0.037 x Total CCS = Peak BH Drain
0.037 x _____ = _____ (A)

Trunks (See Note)

<u>Type</u>	<u>Number</u>	<u>Drain</u>
1W Incoming DD	_____ x 0.30	= _____
1W Incoming NDD	_____ x 1.25	= _____
2W DD	_____ x 0.15	= _____
2W NDD	_____ x 0.62	= _____
CAMA or SATT	_____ x 0.14	= _____
Coin Completion	_____ x 0.35	= _____

Total Trunk Drain _____ (B)

Note: Do not include 1-way outgoing trunks other than CAMA or SATT.

DD = Delay Dial
NDD = Non-Delay Dial

Common Equipment

Common Control and General Office Drain 6.0
Ringing Generators (5 Freq. 15W-3A, 25W-5A, 50W-13A) _____
(1 Freq. 15W-0.6A, 25W-1A, 50W-1.8A)

Detection Equipment (Type 70A - 4 amps/system) _____

Customer Equipment (Carrier, loop extenders, etc.) _____

Total Common Equipment Drain _____ (C)

Total CXP-5 Drain = 0.8 x [A + B + C]
= 0.8 x _____ = _____

Automatic Electric
CXP-5

Example

The following information is used to demonstrate the method used to calculate the current drain of the Automatic Electric CXP-5 system.

2000 Lines
1.6 CCS/Line Originating
Delay Dial Trunks CCS 1000
Local Register Sender CCS 1800
Non-Delay Dial Trunk Register-Sender CCS 400
 10 1W Incoming DD Trunks
 5 1W Incoming NDD Trunks
 20 2W DD Trunks
 5 2W NDD Trunks
 15 CAMA Trunks
 5 Coin Completion
 Ringing Generator - 5 Frequency - 25 Watt
 One 70A System
 40 amps Customer Equipment

EXAMPLE

Automatic Electric CXP-5

Subscriber Lines x CCS/Line =
2000 x 1.6 = 3200
 Delay Dial Trunks CCS = 1000
 Local Register-Sender CCS = 1800
 Non-Delay Dial Trunk Register-Sender CCS = 400
 Total CCS = 6400

0.037 x Total CCS = Peak EH Drain
 0.037 x 6400 = 236.8 (A)

Trunks (See Note)

<u>Type</u>	<u>Number</u>		<u>Drain</u>
1W Incoming DD	<u>10</u>	x 0.30 =	<u>3.0</u>
1W Incoming NDD	<u>5</u>	x 1.25 =	<u>6.3</u>
2W DD	<u>20</u>	x 0.15 =	<u>3.0</u>
2W NDD	<u>5</u>	x 0.62 =	<u>3.1</u>
CAMA or SATT	<u>15</u>	x 0.14 =	<u>2.1</u>
Coin Completion	<u>5</u>	x 0.35 =	<u>1.8</u>
Total Trunk Drain			<u>19.3</u> (B)

Note: Do not include 1-way outgoing trunks other than CAMA or SATT.

DD = Delay Dial
 NDD = Non-Delay Dial

Common Equipment

Common Control and General Office Drain	6.0
Ringling Generators (5 Freq. 15W-3A, 25W-5A, 50W-13A) (1 Freq. 15W-0.6A, 25W-1A, 50W-2.8A)	<u>5.0</u>
Detection Equipment (Type 70A - 4 amps/system)	<u>4.0</u>
Customer Equipment (Carrier, loop extenders, etc.)	<u>40.0</u>
Total Common Equipment Drain	<u>55.0</u> (C)

Total CXP-5 Drain = 0.8 x [A + B + C]
 = 0.8 x 311.1 = 248.9

Exhibit G

Automatic Electric No. 1 - EAX

Line Drain

Number of lines x 0.027 amps/line (A)

Trunk Drain

Number of trunks x 0.15 amps/trunks (B)

Busy Hour Drain = A + B = (C)

Peak Busy Hour Drain = 1.33 x C = (D)

Common Control Drain

Up to 15,000 lines - 250 amps (E)
More than 15,000 lines - 510 amps

Customer Equipment Drain

As Required (F)

Total Busy Hour Drain = C + E + F

Total Peak Busy Hour Drain (Power Board) = D + E + F

Example: The following information is used to demonstrate the method for calculating the busy hour current drain of the Automatic Electric No. 1 - EAX:

4000 Lines -- 800 Trunks -- 100 Amps, Customer Equipment Drain

Calculation:

4000 lines x 0.027 amps/line	=	108 amps
800 trunks x 0.15 amps/trunk	=	<u>120</u> amps
Busy Hour Drain		228 amps

Peak Busy Hour Drain = 1.33 x 228 = 303.2 amps

Common Control Drain = 250 amps

Customer Equipment Drain = 100 amps

Total Busy Hour Drain = 228+250+100 = 578 amps

Total Peak Busy Hour Drain = 303.2+250+100 = 653.2 amps

EXHIBIT H

North Electric NX-1D

Formula 1 for Class 5 offices - includes all trunks:

Average BH Current Drain =
Number of Lines x CCS per line x 0.025 amperes

_____ x _____ x 0.025 = _____

Customer Equipment Drain = _____

Total Drain = _____

Formulae for Class 4/5 offices or Class 5 offices with ticketing:

1. Line Group Drain =
Number of Lines x CCS per line x 0.014 amperes
_____ x _____ x 0.014 = _____
 2. One-way trunk, excluding intertoll, Drain =
Trunks CCS x 0.01 amperes
_____ x 0.01 = _____
 3. Two-way, and one-way intertoll, trunk Drain =
Trunks CCS x 0.0174 amperes
_____ x 0.0174 = _____
 4. Toll Recording Trunk Drain =
Trunks CCS x 0.05 amperes
_____ x 0.05 = _____
 5. TSD Equipment Drain =
TSD CCS x 0.015 amperes
_____ x 0.015 = _____
 6. Customer Equipment Drain = _____
- Total Drain = 1 + 2 + 3 + 4 + 5 + 6 = _____

Calculating drain for Group Selector, Translator and Number Group:

Group Selector and Translator
1.5 amps per frame

Number Group
1.0 amp per frame

EXHIBIT I

North NX-1E

The current drain for the electromechanical portion of the NX-1E is calculated in the same manner as the NX-1D. To calculate the drain of the electronic part of the NX-1E, the following figures should be used:

<u>Uprights</u> <u>Fully Equipped</u>	<u>Average Drain</u> <u>Per Upright</u>
Receiver-Sender Originating (RSO)	11 amps
RSO - Auxiliary	7
Receiver-Sender Incoming (RSI)	10
Key Call Receiver/MF Receiver (KCR/MFR) (Assume all MFR's)	4
KCR/MFR Auxiliary (Assume all MFR's)	4
KCR/MFR (Assume all KCR's)	6
KCR/MFR Auxiliary (Assume all KCR's)	7
Key Call/MF Receiver Link (MFL)	3
Trunk Register Link (TRL)	6
500-Line Group	Number of Lines x UC/L x 0.0075
3-Stage Group Selector	14
CPU Pair	17
Data Memory	15
Miscellaneous Data Transfer Unit	3
Tape Unit	5

North NX-1D and NX-1E

Example

The following data is used to demonstrate the method used to calculate the current drain of the North NX-1D and the electromechanical portion of the NX-1E. The necessary information to calculate the required drain of the NX-1E electronic circuits is shown in Exhibit I.

Class 5 Office		
2000 Lines		
2.0 CCS/Line Originating		
Customer Equipment Drain	40 Amps	
Class 5 Office with Ticketing		
2000 Lines		
2.0 CCS/Line Originating		
100 Two-Way Intertoll Trunks	2800 CCS	
100 Two-Way EAS Trunks	2800 CCS	
75 One-Way Toll Completing		
Trunks	2000 CCS	
75 One-Way Intertoll Trunks	2000 CCS	
125 Toll Recording Trunks	3600 CCS	
12 TSD Positions	1200 CCS	
Customer Equipment Drain	40 Amps	

EXAMPLE

North Electric NX-1D

Formula 1 for Class 5 offices - includes all trunks:

Average EH Current Drain =
Number of Lines x CCS per line x 0.025 amperes

$$\begin{array}{r} \underline{2000} \times \underline{2.0} \times 0.025 = \underline{100} \\ \text{Customer Equipment Drain} = \underline{40} \\ \text{Total Drain} = \underline{140} \end{array}$$

Formulae for Class 4/5 offices or Class 5 offices with ticketing:

1. Line Group Drain =
Number of Lines x CCS per line x 0.014 amperes
$$\underline{2000} \times \underline{2.0} \times 0.014 = \underline{56.0}$$
 2. One-way trunk, excluding intertoll, Drain =
Trunks CCS x 0.01 amperes
$$\underline{2000} \times 0.01 = \underline{20.0}$$
 3. Two-way, and one-way intertoll, trunk Drain =
Trunks CCS x 0.0174 amperes
$$\underline{7600} \times 0.0174 = \underline{132.2}$$
 4. Toll Recording Trunk Drain =
Trunks CCS x 0.05 amperes
$$\underline{3600} \times 0.05 = \underline{180.0}$$
 5. TSD Equipment Drain =
TSD CCS x 0.015 amperes
$$\underline{1200} \times 0.015 = \underline{18.0}$$
 6. Customer Equipment Drain = 40.0
- Total Drain = 1 + 2 + 3 + 4 + 5 + 6 = 446.2

EXHIBIT J

Northern Electric SP-1 (2 Wire)

I. Negative 48-Volt Current Consumption

Constant		125 amps
<u>Total Busy Hour Calls</u> x 1 amp	=	
1000		
(Minimum 10 amperes)		
Incoming CCS x 0.01	=	
Outgoing CCS x 0.00925	=	
Originating Intraoffice CCS x 0.0145	=	_____
Total Negative 48-Volt Current Drain	=	

Notes:

1. In offices with short loops, add 20 amperes per 10,000 lines. Where loops are long, subtract 20 amperes per 10,000 lines.
2. For offices with Centrex features, add 25 amperes.

II. Positive 24-Volt Current Consumption

A. Common Equipment (CPU's, CCTC, FMC, etc.)	42.0 amps
B. Call Stores:	
Ferrite Sheet Memory, Basic 16K Words	10.8 amps
, First Supplementary 8K Words	8.0 amps
, Second Supplementary 8K Words	2.8 amps
MOS Memory, Basic 16K Words	5.1 amps
, Supplementary 8K Words	1.3 amps
C. Program and Data Stores:	
Piggyback Twister Memory, Basic 16K Words	5.2 amps
, Supplementary 16K Words	2.2 amps
MOS Memory, Basic 32K Words	13.8 amps
, Supplementary 16K Words	5.2 amps
D. Centrex Data Line Units (16 Data Lines)	8.0 amps
E. LAMA	3.0 amps
F. Per 1000 Line Appearances	1.0 amps

Northern Electric SP-1

Example

The following data is used to demonstrate the method of calculating the negative 48-volt current drain of the Northern Electric SP-1 system.

Total Busy Hour Calls (Originating and Terminating)	12,000 BHC
Incoming CCS	3000 CCS
Outgoing CCS	3000 CCS
Originating Intraoffice CCS	4000 CCS

The majority of subscriber loops are 1900 ohms or less.

EXAMPLE

Northern Electric SP-1 (2 Wire)

I. Negative 48-Volt Current Consumption

Constant		125 amps
<u>Total Busy Hour Calls x 1 amp</u>	$\frac{12,000}{1,000} \times 1$	= 12
(Minimum 10 amperes)		
Incoming CCS x 0.01	$3000 \times .01$	= 30.0
Outgoing CCS x 0.00925	$3000 \times .00925$	= 27.8
Originating Intraoffice CCS x 0.0145	$4000 \times .0145$	= 58.0
Total Negative 48-Volt Current Drain		= 252.8
Add for short loops		+ 20.0
		272.8

Notes:

1. In offices with short loops, add 20 amperes per 10,000 lines. Where loops are long, subtract 20 amperes per 10,000 lines.
2. For offices with Centrex features, add 25 amperes.

EXHIBIT K

Nippon Electric Crossbar Systems
(NC-10, NC-23, NC-400 and NC-460)

I. Negative 48-Volt Main Power Requirement

A. Average Current Drain

$$I_{av} = (A+B) \times C \times \frac{K}{36} \text{ where}$$

I_{av} = Average Current in Amperes

A = Originating CCS Per Line

B = Terminating CCS Per Line

C = Number of Lines

K = 0.41 for NC-10

K = 0.51 for NC-23

K = 0.53 for NC-400 and NC-460

B. Peak Current Drain

$$I_{pk} = I_{av} + 4.48 \sqrt{I_{av}} \text{ where}$$

I_{pk} = Peak Current in Amperes

I_{av} = Average Current in Amperes

II. Positive 50-Volt Power Requirement

A. 0.58 amps per Dial Tone Marker (NC-400)

B. 1.42 amps per Completing Marker (NC-400)

C. 1.42 amps per Marker (NC-23, NC-460)

Nippon Electric Crossbar Systems

Example

The following data is used to demonstrate the method of calculating the current drain for the NC-10, NC-23, NC-400 and NC-460 systems.

Originating CCS Per Line	1.6 CCS/Line
Terminating CCS Per Line	1.6 CCS/Line
Number of Lines	2000 Lines
Dial Tone Markers (NC-400)	3
Completing Markers (NC-400)	3
Markers (NC-23, NC-460)	3

Negative 48-volt Main Power Requirement:

NC-10

$$I_{av} = (1.6 + 1.6) \times 2000 \times \frac{.41}{36} = 73 \text{ amps}$$

$$I_{pk} = 73 + 4.48 \sqrt{73} = 111.3 \text{ amps}$$

NC-23

$$I_{av} = (1.6 + 1.6) \times 2000 \times \frac{.51}{36} = 90.7 \text{ amps}$$

$$I_{pk} = 90.7 + 4.48 \sqrt{90.7} = 133.3 \text{ amps}$$

NC-400 and NC-460

$$I_{av} = (1.6 + 1.6) \times 2000 \times \frac{.53}{36} = 94.2 \text{ amps}$$

$$I_{pk} = 94.2 + 4.48 \sqrt{94.2} = 137.7 \text{ amps}$$

Positive 50-volt Power Requirement:

NC-23 and NC-460

$$3 \times 1.42 = 4.26 \text{ amps}$$

NC-400

$$3 \times 0.58 + 3 \times 1.42 = 6 \text{ amps}$$

EXHIBIT L

Power Requirements for Stromberg-Carlson
Toll Ticketing Equipment

The following busy hour current drains should be used when calculating power requirements for Stromberg-Carlson automatic toll ticketing equipment:

- 1.0 ampere per recorder
- 2.0 amperes per identifier (usually 1 identifier)
- 4.0 amperes per data register (1 register/3.5 trunks)
- 2.0 amperes per sender (1 sender/4 recorders)
- 4.0 amperes miscellaneous

Example:

An automatic toll ticketing system contains the following equipment: 17 recorders, 1 identifier, 4 data registers and 4 senders.

The following drains are totaled:

Recorders	17 x 1.0	=	17
Identifier	1 x 2.0	=	2
Data Registers	4 x 4.0	=	16
Senders	4 x 2.0	=	8
Miscellaneous			<u>4</u>
Total Drain			47 amperes

EXHIBIT M

ITT Tel Touch

The following formulae should be used to calculate the additional busy hour current drain when ITT Tel Touch (pushbutton dialing) equipment is installed:

1. Total Originating Call Drain

$$\frac{\text{Total Originating Traffic (UC)} \times 0.046}{36} = \text{_____ amps}$$

2. Traffic to Register Drain*

$$\frac{\text{BHC} \times \text{Register Holding Time} \times (\text{Register Current} + 0.04)}{3600} = \text{_____ amps}$$

$$\text{BHC} = \frac{\text{Unit Calls} \times 100}{\text{Call Holding Time}}$$

$$\text{Register Holding Time (RHT)} = 2.5 + (1.5 \text{ seconds/digit} \times \text{number of digits})$$

*Repeat this calculation for each type of traffic to registers, i.e., local, toll, CAMA, EAS, etc.

Register Current Table

<u>Number of Digits Handled</u>	<u>Current</u>
1	1.2
2	1.2
3	1.5
4	1.5
5	1.65
6	1.65
7	2.0
8	2.0
9	2.3
10	2.3
11	2.55
12	2.55
13	2.8

Exhibit M Continued-2

3. Allotter Drain

$$\text{Total BHC} \times 0.00047 = \underline{\hspace{2cm}} \text{ amps}$$

4. Peak Drain

$$\text{Total Drain} (1 + 2 + 3) \times 1.03 = \underline{\hspace{2cm}} \text{ amps}$$

Example:

A 300-line office equipped with 100% Tel Touch has the following traffic parameters:

$$\begin{aligned} \text{Total Originating Traffic} &= 300 \text{ lines} \times 1.4 \text{ UC/L} = 420 \text{ UC} \\ 9 \text{ Toll Trunks} &= 126 \text{ UC} + 2 = 63 \text{ UC} \\ 7 \text{ EAS Trunks} &= 84 \text{ UC} + 2 = 42 \text{ UC} \end{aligned}$$

Equal traffic is assumed in both directions on 2-way trunks.

$$\text{Total Local Originating Traffic} = 420 - (63 + 42) = 315 \text{ UC}$$

Assume 120 second holding time.

$$\text{Local Originating BHC} = \frac{315 \times 100}{120} = 263 \text{ BHC}$$

Toll holding time is assumed to be 270 seconds.

$$\text{Toll Originating BHC} = \frac{63 \times 100}{270} = 23 \text{ BHC}$$

EAS holding time is assumed to be 150 seconds.

$$\text{EAS Originating BHC} = \frac{42 \times 100}{150} = 28 \text{ BHC}$$

Local Traffic - 7 Digits
Toll Traffic - 1 Digit
EAS Traffic - 7 Digits

$$\text{Register Holding Time (RHT) - Local and EAS} = 2.5 + (1.5 \times 7) = 13 \text{ seconds}$$

$$\text{Register Holding Time (RHT) - Toll} = 2.5 + (1.5 \times 1) = 4 \text{ seconds}$$

Exhibit M Continued-3

The following shows the calculation of the busy hour current drain:

1. Total Originating Call Drain = $\frac{420 \times .046}{36}$ = .54 amps
2. Local Traffic to Register Drain = $\frac{263 \times 13}{3600} \times (2+.04)$ = 1.94 amps
- EAS Traffic to Register Drain = $\frac{28 \times 13}{3600} \times (2+.04)$ = .21 amps
- Toll Traffic to Register Drain = $\frac{23 \times 4}{3600} \times (1.2+.04)$ = .03 amps
3. Allotter Drain = $(263 + 28 + 23) \times .00047$ = .15 amps
- Total Drain = 2.87
4. Peak Drain = $2.87 \times 1.03 = 3.0$ amps

EXHIBIT N

Stromberg-Carlson Tone Dialing

To calculate the current drain of Stromberg-Carlson tone dialing equipment, use one ampere for each converter.

To calculate the number of converters required, use the following formula:

$$\frac{\text{Number of Lines} \times \text{UC/L} \times \text{Average Converter Holding Time}}{\text{Avg. Call Holding Time}} = \text{UC to Converters}$$

Using the P.01 Table, find the number of converters required.

Example:

Given:

400 Lines

1.5 UC/L

Call Holding Time - 180 seconds

Converter Holding Time - 10 seconds

Find current drain of Tone Dialing equipment.

Using the above formula, the traffic to the converters is

$$\frac{400 \times 1.5 \times 10}{180} = 33.3 \text{ UC}$$

From the P.01 Table, 5 converters are required. Therefore, the current drain is

$$5 \times 1 \text{ amp/converter} = 5 \text{ amps}$$